

Sentinel Series Access Control

LT Security Inc.

2026

LT SECURITY INC.

17333 FREEDOM WAY, CITY OF INDUSTRY, CA 91748

626-435-2838

626-435-2815

Contents

- 1. Introduction 5
 - 1.1. Home Screen and Menus 5
 - 1.2. Using List Views 9
 - 1.3. Using Property Views 11
 - 1.4. Logging In and Passwords 11
 - 1.5. Licenses 12
 - 1.6. Notifications 13
 - 1.7. Emergency Features 14
- 2. Monitoring 14
 - 2.1. Events 15
 - 2.2. Alarms 17
 - 2.3. Door Status 19
 - 2.4. Controller Status 21
 - 2.5. Sub-Controller Status 22
 - 2.6. Reader Status 23
 - 2.7. Maps 24
 - 2.8. Reports 26
 - 2.8.1. Audits 27
 - 2.8.2. Muster 28
 - 2.8.3. Users With Access Level 29
 - 2.8.4. Users With Access to Door 29
 - 2.8.5. Schedules 30
 - 2.8.6. Access Levels 30
 - 2.8.7. Doors 30
 - 2.8.8. Users 31
 - 2.8.9. Event History 31

2.8.10.	Alarm History.....	32
3.	Access Control.....	33
3.1.	Users.....	34
3.1.1.	User Properties.....	37
3.1.2.	Printing Cards.....	42
3.1.3.	Importing Users from a CSV File.....	42
3.2.	Shared Access Codes.....	47
3.3.	Emergency Codes.....	49
3.4.	Access Levels.....	50
3.5.	Schedules.....	51
3.6.	Door Mode Schedules.....	52
3.7.	Special Days.....	53
4.	Configuration.....	54
4.1.	Understanding Controllers and Doors.....	55
4.2.	Hardware.....	56
4.2.1.	Models and Configurations.....	57
4.2.2.	Modifying Controller Configuration.....	59
4.2.3.	Hardware Properties.....	60
4.2.4.	Adding Controllers.....	68
4.2.5.	Software Updates.....	69
4.2.6.	Resync All.....	70
4.2.7.	I/O Expansion Sub-Controllers.....	70
4.3.	Doors.....	72
4.3.1.	Door Properties.....	74
4.4.	Locations.....	79
4.5.	Areas.....	80
4.6.	Maps.....	81
4.7.	Card Designs.....	82

4.8.	Card Formats	85
4.9.	Alarm Triggers	87
4.10.	Door Templates	87
4.11.	Hardware Templates	89
5.	Administration	90
5.1.	User Roles	90
5.2.	System Settings	96
6.	Features and Tasks	97
6.1.	Lockdown	97
6.2.	Duress.....	99
6.3.	Reports and Printing	100
6.4.	Manual Commands	100
6.5.	First Credential Unlock	101
6.6.	OSDP Devices	101
6.7.	Card Enrollment Points	104
6.8.	Anti-Passback	105
6.9.	Elevator Control	107
7.	Reference	107
7.1.	Glossary	108
7.2.	Event Categories and Types	114
7.3.	Door Modes.....	121

1. INTRODUCTION

- Support for industry-standard OSDP and Wiegand card readers, with flexible card format definitions
- Critical [emergency functions](#): [global lockdown](#), global emergency unlock, [alarm management](#), [duress PINs](#), [emergency codes](#), and [muster reporting](#)

Using this Guide

The topics in this introduction explain the general use of Sentinel Series.

There are four main topics corresponding to the navigation menus: [Monitoring](#), [Access Control](#), [Configuration](#), and [Administration](#), with sub-topics for each menu item.

[Features and Tasks](#) covers topics that go beyond a single screen.

[Reference](#) includes the [Glossary](#) and other reference material.

Getting Started

To get started:

1. Open a web browser and [log into](#) Sentinel Series.

You now have a fully functioning access control system. Read about [Monitoring](#) and [Notifications](#) so you can see what's going on in your system.

Important: After getting started, learn to use the Sentinel Series [Emergency Features](#). Some of these require setup before you can use them to protect your Users.

1.1. HOME SCREEN AND MENUS

The Home Screen displays a dashboard-style summary of Sentinel Series, including recent Event activity. The Menu Bar is available on this screen, as it is on every screen in the application.

Home Screen Dashboard

Potential security issues and problems are highlighted in red, including [Lockdown](#) and Emergency Unlock counts. You can click the links for more information. You can always return to this screen using the **Home** button towards the upper right on the Main Menu.

The dashboard summary squares include:

- Controllers status summary — link takes you to [Hardware](#)
- Doors status summary — link takes you to [Door Status](#)
- Web connected client count, and whether the Admin password has been secured (Go to the [Users](#) module and change the Admin password to secure it.)
- Recent Events — + **View More** link takes you to [Events](#)

The exact summary squares visible depend on your User Role.

Main Menu

The Main Menu bar is at the top right of all screens.

Lockdown and
Clear Lock-
down



Click **Lockdown** to quickly lock all Doors in an emergency situation. When a global lockdown is in effect, a message is displayed prominently in the Menu Bar. Note that initiating a lockdown will create an [Alarm](#) by default.

Click **Clear Lockdown** to re-enable access and return Doors to their default or Scheduled Door Mode.

See [Lockdown](#) for more information.

Alarms 

When there are active Alarms, this icon will be red or yellow, and show the number of current Alarms. Click to go to the [Alarms](#) screen.

Notifications 

Click to view the [Notifications](#) you have subscribed to. The number of Notifications waiting for you is displayed under the icon.

Home 

Return to the Home Screen.

Layouts 

Layouts allow you to view multiple features or screens at a time. For example, select a 3-panel layout to work on [Access Levels](#) and [Schedules](#) while viewing live [Events](#). Note that each panel has its own navigation menu.

Select the single-pane layout to return to the standard view.

Menu 

Opens a menu showing several items relevant to your logged-in session. [See below.](#)

The exact Main Menu items available depend on your [User Role](#).

The Navigation Menu contains items for all of the main screens in the application, organized into four category menu buttons: [Monitoring](#), [Access Control](#), [Configuration](#), and [Administration](#).



Use the **Back** and **Forward** buttons to navigate through your own history of accessing the screens. (The browser's navigation buttons do not work inside Sentinel Series).



The exact Navigation Menu items available depend on your [User Role](#).

Menu Button Items

- | | |
|-----------------|--|
| Language | Switches the language for the current logged-in session. |
| Preferences | Sets your preferences: <ul style="list-style-type: none">• Items per Page - the number of items shown in one page of a list• Card Enrollment Point |
| Change Password | Allows you to change your password . |
| Help | Opens this Help. |
| About | Opens a window showing product information, including your current version. |

Sign Out Log out of Sentinel Series, returning to the [Login Screen](#).

1.2. USING LIST VIEWS

List Views show a list of items in columns. In many cases, the columns can be changed, moved around, and searched.


Note that [Property Views](#) also display a list on the left, which has the same controls.

Some List Views have an enhanced filter or search feature instead of the following controls.

Searching

To search in a column, enter the text in the box at the top of the list.


The default, gray text is the column that will be searched. Click the magnifying glass to change the column.



Column Selection

You can move the displayed columns by clicking and dragging on the column title.

Click the triple bar icon to select which columns to show.



Paging

Lists run to extra pages when the number of items exceed your personal **Items per Page** set in [Menu: Preferences](#).

This box appears at the bottom of the list when there are pages. You can go forward or back a page, go to the end or beginning, or enter a page number.



1.3. USING PROPERTY VIEWS

Most configuration is viewed or changed in Property Views. These screens display a list of items you have created on the left, with their properties on the right.

The list can be searched using the same tools as in [List Views](#).

Use the buttons above the properties to create new items, save changes, or delete items.



Create



Save



Cancel



Delete

Many Property Views add additional action buttons to the menu bar. These are generally specific to the screen they are displayed on, and their functions are described in the documentation for the specific screens. These are disabled if they don't apply to the currently selected item.



Upload Firmware



Modify



Discover Controllers

1.4. LOGGING IN AND PASSWORDS

To open Sentinel Series, go to the address your administrator gave you in your web browser. If it doesn't load automatically, try adding "https://" before it. Once it's open, save the link as a bookmark for easy access.

Enter the username and password provided by your administrator.

After you are successfully logged in, you will see the [Home Screen](#).

Changing your Password

Once you are logged in, you may change your password from the upper-right [Menu](#).

Password Strength

Passwords have the following minimum strength requirements:

- At least 9 characters long
- At least one uppercase letter
- At least one lowercase letter
- At least one number
- At least one special character

1.5. LICENSES

Additional licenses can be used to add features, or increase the capacity of Sentinel Series. For example:

- increase the number of [Doors](#) or [Secondary Controllers](#) allowed
- add to the languages the system supports

(Note that "Out" Doors are not counted towards your maximum authorized doors.)

Contact your authorized Sentinel Series representative for license upgrades. Current license information can be viewed on the [About](#) screen.

How to Add Licenses

When you acquire an additional license, you will receive a license file from your authorized Sentinel Series representative. Save this file on your computer, then:

1. Select **Menu: About**.
2. Click the **Upload Additional Licenses** button.
3. Click on the **Browse** button, and **Open** the license file you received.
4. Click **OK**. Your new capabilities should be listed on the About screen.

Related Topics

- [Home Screen and Menus](#)

1.6. NOTIFICATIONS

Notifications allow you to select certain [Events](#) you want brought to your attention. When one of these Events occurs, it will appear in your Notification window and remain there until you clear it.

Notifications can be copied to you by email.

Click the **Notifications** icon in the Menu Bar to open and close the Notifications Window at the bottom of the screen.

▣ Configuring Notifications

Configure Notifications to select the Events that generate Notifications for the current User. No Notifications are created unless you select them.

- Click **Notifications** on the Menu Bar.
- Click the **Configure notifications** link in the Notifications Window.
- If desired, check **Send a Copy of Notifications by Email**. You must have a valid email address configured in [Users](#). You may need an administrator to set this, if you do not have permissions.
- Check the Event categories and types you wish to receive Notifications for. Select a category to receive Notifications for all Event Types in that category, or expand the category and select specific Event Types.
- Click **Save**.

▣ Clearing Notifications

To clear Notifications in the list, click one of the buttons next to **Configure notifications**.

-  — Select one or more Notifications and click this to clear them.
-  — Click to clear all Notifications.

▣ Related Topics

- [Users](#)
- [Events](#)
- [System Settings](#)

1.7. EMERGENCY FEATURES

Sentinel Series is designed with a number of important features used to aid in a variety of emergency situations.

- [Lockdown](#) can be configured and used to secure facilities against an active intruder or threat.
- Emergency unlock can be configured and used to aid access by emergency personnel in the event of an active emergency condition signaled from another system
- [Duress PINs](#) can be used to allow users to signal a duress condition during their otherwise normal access
- [Emergency Codes](#) can be configured and used to allow access to emergency or security personnel using a PIN-code only, regardless of Door Mode (including lockdown), or Multi-User Access Rules.
- [Muster](#) can be used to aid in the tracking of users during an evacuation, or evacuation drill
- [Alarms](#) and [Notifications](#) can be configured and used to make sure the correct personnel are aware of potential emergency situations

Important: All emergency functions intended to be used in Sentinel Series should be tested ahead of time, to ensure that everything is configured and working correctly.

Important: These emergency functions are designed as a supplement to, but not a replacement for, life-safety infrastructure for your facility. Life-safety functions are regulated by country- and region-specific fire codes. Please refer to these when designing and configuring Sentinel Series to ensure compliance.

2. MONITORING

Monitoring gives you live views of what is occurring in Sentinel Series, and printable reports of configuration and history.

Live Monitoring

[Events](#) is a live view of activity in Sentinel Series.

[Alarms](#) shows Events that you have determined should be immediately reviewed and action taken. Each Alarm must be acknowledged and cleared by someone who has resolved the problem. Note that Events do not become Alarms until you set up [Alarm Triggers](#).

[Door Status](#) shows the real-time status of all Doors, including whether they are online/offline, locked/unlocked, open/closed, and any errors or alarms.

[Controller Status](#) shows the real-time status of all Controllers, including whether they are online/offline.

[Sub-Controller Status](#) shows the real-time status of Sub-Controllers, including whether they are online/offline.

[Reader Status](#) shows the real-time status of Readers, in particular OSDP Readers, including whether they are online/offline, and information on encryption, software version, and serial number.

[Maps](#) show similar status as Door Status, with visual indicators displayed on a Map of your facilities. The Maps must first be created in [Maps \(Configuration\)](#).

Reports

[Reports](#) provides exportable/printable reports on Users, configuration, and history.

▣ Related Topics

- [Reports and Printing](#)

2.1. EVENTS

Events displays a real-time list of Events occurring within Sentinel Series. Events that trigger [Alarms](#) are displayed in a configurable color.

To receive an email when important Events occur, see [Notifications](#).

Up 1000 Events can be displayed. To view more Events, use [Event History](#).

Menu Buttons

Filter Opens a panel where you can restrict the Events you wish to see in the list view. Your filters remain in place each time you log in.

Settings take effect when you click the **Search** button, at the bottom of the panel. The **Reset** button clears all filters.

User and Device Filters

The display shows only the Events that match *all* the filters you specify. Note that the **Name** filters are case-insensitive, and will find partial matches. For instance, if you enter "john", the display will also show Events for "John", or "Johnny".

Event Type Filter

The display shows Events that match *any* of the Event Types you have checked. If nothing is checked, all Events are displayed.

Clear Clear the current list of Events from the display, so only new Events appear. Events are hidden, but not deleted.

Events Columns

Icon Category of Event

Occurred When the Event actually occurred (as determined by the hardware on which it occurred)

Note: if the date and time reported by the hardware is more than a year in the past, or more than a minute in the future, the event will be flagged as **Inaccurate Time**.

Description Text of the Event

User	The User associated with the Event. This could also be a Shared Access Code , Emergency Code , or credential information (card number, PIN) that is not assigned to a single User.
Source	The device that recorded the Event. For door access Events, this is a Door. For other Events, this may be a Controller, input, output, or other device.
Recorded	(Hidden by default) The time the Event was received and recorded by the Primary Controller. This only differs from Occurred if the Secondary Controller where it occurred was offline with the Primary Controller at the time of the Event.
Controller	(Hidden by default) Controller where the Event occurred, or Controller managing the device where the Event occurred.
Area	(Hidden by default) If the Event is associated with an Area (for example a Door entering an Area), the Area is indicated here.
Location	(Hidden by default) If the source is associated with a Location , it is indicated here.

▣ Related Topics

- [System Settings](#)
- [Event History](#)
- [Notifications](#)

2.2. ALARMS

Alarms are issues that may indicate a potential security threat or other problem. They cause a warning display on the [Main Menu](#) bar, and they remain in effect until they are resolved by a User.

Alarms are triggered by [Events](#). Some [Event Types](#) are set to trigger Alarms by default. You can make more Events trigger Alarms, or change the defaults, in [Alarm Triggers](#).

To receive an email when an Event causes an Alarm, see [Notifications](#).

The color of an Alarm is determined by its state, which can be:

- **New** (Red) — this means the Alarm is active.
- **Acknowledged** (Yellow) — this means that some User has acknowledged the Alarm.

Resolved Alarms are removed from the list. They can be viewed in [Alarm History](#).

Repeated Alarms are merged into a single Alarm. The **Count** column shows how many times it has occurred, and **Last Recorded** shows the most recent time it occurred. Alarms are merged when they are identical in all ways except for the date and time. Once resolved, any new occurrence will make a new Alarm.

Menu Buttons

Acknowledge Acknowledges selected Alarms that are in the **New** state, changing the state to **Acknowledged**. Acknowledgment Indicates that the User is aware that the Alarm has occurred. Note that depending on the configuration of the corresponding [Alarm Trigger](#), the Alarm may start off in the **Acknowledged** state instead of the **New** state.

Resolve Resolves all Alarms that are in the **Acknowledged** state, changing the state to **Resolved**. Resolution indicates that any underlying problem has been dealt with, or that it was a false alarm, for example. The Alarm will be removed from this screen, but can be viewed in [Alarm History](#). Alarms must be acknowledged before they can be resolved.

Alarms Columns

Description Description of the triggering Event

Source	The device that recorded the Event. For Access Point access Events, this is an Access Point. For other Events, this may be a Controller, or other device.
Priority	The priority of this Alarm (as configured in Alarm Triggers)
Count	The number of times the triggering Event has occurred and merged into one Alarm
First Recorded	Time of the first triggering Event
Last Recorded	Time of the most recent duplicate triggering Event
State	New or Acknowledged . The Resolved state is only visible in Alarm History . The state determines the color (see above).
Location	Location where the triggering Event occurred
Area	(hidden by default) Area where the triggering Event occurred

▣ Related Topics

- [Alarm Triggers](#)
- [Alarm History](#)
- [Emergency Features](#)

2.3. DOOR STATUS

Door Status displays a real-time list of all Doors and their status. You can also use [Manual Commands](#) to unlock a Door momentarily or change the Door Mode.

Menu Buttons

**Manual Com-
mands** Send a [Manual Command](#) to the selected Door, such as to momentarily unlock it or change its Door Mode.

Columns

Door The name of the Door

**Communica-
tions** **Online** or **Offline**

Door Mode The [Door Mode](#), such as **Card Only** or **Card and PIN**

Status Whether the Door is **Locked** or **Unlocked**, and **Open** or **Closed**

Errors Shows **Door Forced**, or **Door Held**, **Reader Offline**, and **Tamper** errors

Alarm Indicates if an active [Alarm](#) exists for the Door

Type The type of Door

- **In**
- **Out**
- **Muster Point**
- **Card Enrollment Point**

Location The Door's [Location](#)

☰ Related Topics

- [Manual Commands](#)

2.4. CONTROLLER STATUS

Controller Status displays a real-time list of all Controllers and their status. This display does not include Sub-Controllers. You can perform certain maintenance tasks such as Resync, Reboot, and Software Updates.

Menu Buttons

Resync Resynchronizes the data on selected Controllers.

Reboot Reboots selected Controllers.

Resync All Resynchronizes the data on all Controllers. See [Resync All](#).

Upload Software Update See [Software Updates](#).

Update Software See [Software Updates](#).

Status Columns

Name The name of the Controller

Status A summary of the status

Communications **Online** or **Offline**

Model	The model of the Controller
Software Version	The software version of the Controller
Serial Number	The serial number of the Controller
Location	The Controller's Location

Related Topics

- [Hardware](#)
- [Resync All](#)
- [Software Updates](#)

2.5. SUB-CONTROLLER STATUS

Sub-Controller Status displays a real-time list of all Sub-Controllers and their status. This display does not include internal I/O Sub-Controllers. You can perform maintenance tasks such as Reboot, and Update Software, and Configure (for OSDP Sub-Controllers).

Menu Buttons

Reboot	Reboots selected Sub-Controllers.
Configure	Opens the OSDP Configuration Wizard. See OSDP Devices .

Status Columns

Name	The name of the Sub-Controller
Status	A summary of the status
Communications	Online or Offline
Model	The model of the Sub-Controller
Software Version	The software version of the Sub-Controller
Serial Number	The serial number of the Sub-Controller
Location	The Sub-Controller's Location

▣ Related Topics

- [Hardware](#)

2.6. READER STATUS

Reader Status displays a real-time list of all Readers and their status. It is primarily useful for OSDP Readers.

Menu Buttons

Configure Opens the OSDP Configuration Wizard. See [OSDP Devices](#).

Columns

Name	The name of the Reader
Status	Status summary
Communications	Online or Offline , and encryption information
Address	The address of the Reader on the Sub-Controller (I/O)
OSDP/RS-485 Address	The "polling address" of the OSDP or RS-485 reader.
Sub-Controller	The Sub-Controller (I/O) which this Reader is a part of.
Managed By	The Door that this Reader is managed by
Software Version	The Reader's software version, if known
Serial Number	The Reader's serial number, if known
Location	The Reader's Location

▣ Related Topics

- Readers
- [OSDP Devices](#)

2.7. MAPS

The Maps view is used to show the status of your Doors and Controllers on graphical backgrounds, for example, on Maps of your building or campus. It highlights all problems in red, and allows sending commands to Doors. Maps may also have links to other Maps for easy navigation.

In this example there are four Doors and one Controller. One of the side doors is offline and should be checked on. Gray icons represent normal operation.



Click to enlarge.

Before they can be viewed, Maps must be created and configured in the [Maps \(Configuration\)](#) screen.

Menu Buttons

Manual Commands Click on a Door to enable the Manual Commands button, allowing commands such as momentarily unlocking it, or changing its mode. See [Manual Commands](#).

Zoom In / Zoom Out Make the Map larger or smaller. When zoomed in, you can click and drag on the Map to see different areas.

Related Topics

- [Maps \(Configuration\)](#)

- [Manual Commands](#)

2.8. REPORTS

Reports provides exportable/printable reports of Users, configuration and history.

There are several options which are common to many or all reports:

- **Orientation: Portrait, or Landscape**
- **Generate:** generates the report, viewable on the same screen
- **Export as PDF:** exports the report to PDF
- **Save as Custom Report:** saves the current settings to a Custom Report, available under **Custom Reports** (towards the bottom of the list of report types).

Reports

[Audits](#) shows configuration changes and actions performed by Users logged into Sentinel Series.

[Muster](#) is a special report that can show you where Users are in an emergency or an evacuation drill. To use the Muster report, you should first designate Muster Areas. Users must check in at the Muster Areas to indicate that they are safely out of the facility.

[Users With Access Level](#) shows which Users have a specific [Access Level](#).

[Users With Access to Door](#) shows which Users have access to a specific Door. This report includes Doors directly assigned to the Users as well as those assigned via an [Access Level](#).

[Schedules](#) is a report of [Schedules](#) and [Door Mode Schedules](#).

[Access Levels](#) is a report of [Access Levels](#).

[Door Report](#) is a report of [Doors](#).

[Users](#) is a report of [Users](#).

[Event History](#) is a report view of [Events](#), with the ability to display a larger number Events and export to CSV and PDF.

[Alarm History](#) shows all [Alarms](#), including those that have been resolved (resolved Alarms are not shown on the live Alarms screen).

Related Topics

- [Reports and Printing](#)

2.8.1. AUDITS

Audits lists configuration changes and actions performed by Users of Sentinel Series. Use these reports to see who unlocked an Access Point, gave access to a User, configured Access Levels, and other system operations.

When generating the report, you are prompted for the following options. Options vary based on the Audit Type selected. Click **Generate** to create the report.

Report Options

- | | |
|-------------|--|
| Orientation | Displays the report in Portrait or Landscape view |
| Audit Type | <ul style="list-style-type: none">• Database Change — shows changes to items in the database (Users, Access Points, Access Levels, etc.), and enables further filtering options.• Manual Command — shows Manual Commands executed on Access Points, and enables further filtering options.• Any/All — both of the above |
| User | If selected, the report will only show actions taken by a specific User. |
| From / To | Limits the report to a date range |
| Change Type | For Database Change , which types of changes to include: <ul style="list-style-type: none">• Inserted• Updated• Deleted• Any/All |

Object Type	For Database Change , which types of items to include (User, Access Point, etc.)
Manual Command	For Manual Command , limits the report to one command type
Device	For Manual Command , limits the report to a single Access Point or Controller

Related Topics

- [Reports and Printing](#)
- [Users](#)
- [Manual Commands](#)

2.8.2. MUSTER

The **Muster** report shows the last known location of Users who are *not* registered in a safe Area. Use this report when evacuating a building or buildings or performing an evacuation drill. This lets security personnel know who is still inside the building(s).

Users counted as "safe" are

- Users who have exited to Global Out or reported at a Muster Point and
- Users who have not used any Door within 24 hours.

Muster reports may or may not include Users who have used a Shared Access Code or Emergency Code.

Creating a Muster Point

A Muster Point can be added at Controller creation time for [1-door Controller models](#).

1. Go to [Hardware](#).
2. Select a 1-door model.

3. For **Configuration**, select an option which includes a Muster Point, such as **In Only + Muster Point**.

You can also modify Controllers after creation, to have Muster Points. For example:

1. Go to [Hardware](#).
2. Select a Controller.
3. Turn the spare readers into Muster Points.

Generating a Muster Report

1. Go to **Muster**. A list of existing muster points is displayed at the bottom.
2. Select **List By — Last Name** or **Area**.
3. Select **Orientation — Landscape** or **Portrait**.
4. Click **Generate**.

Related Topics

- [Reports and Printing](#)
- [Hardware](#)
- [Emergency Features](#)

2.8.3. USERS WITH ACCESS LEVEL

Users With Access Level creates a report of all [Users](#) who have a selected [Access Level](#).

This report does not include [Shared Access Codes](#) or [Emergency Codes](#).

Related Topics

- [Reports and Printing](#)
- [Users](#)
- [Access Levels](#)

2.8.4. USERS WITH ACCESS TO DOOR

Users With Access to Door creates a report showing which [Users](#) have access to a specific Door. This report includes Doors directly assigned to the Users as well as those assigned via an Access Level.

This report does not include [Shared Access Codes](#) or [Emergency Codes](#).

This report also excludes Users with no credentials (no cards).

Related Topics

- [Reports and Printing](#)
- [Users](#)
- [Access Levels](#)

2.8.5. SCHEDULES

Schedules creates a report of all [Schedules](#) and [Door Mode Schedules](#).

Related Topics

- [Reports and Printing](#)
- [Schedules](#)
- [Door Mode Schedules](#)

2.8.6. ACCESS LEVELS

Access Levels creates a report of all [Access Levels](#).

Related Topics

- [Reports and Printing](#)
- [Access Levels](#)

2.8.7. DOORS

Doors creates a report of all [Doors](#), or a selected Door.

Related Topics

- [Reports and Printing](#)
- [Doors](#)

2.8.8. USERS

Users creates a report of all [Users](#), or a selected User.

Related Topics

- [Reports and Printing](#)
- [Users](#)

2.8.9. EVENT HISTORY

Event History displays a list of Events according to a filter, and allows export to CSV and PDF. The maximum number of Events in this screen is limited only by the number of Events in the database. For a real-time view, see [Events](#).

Menu Buttons

Export CSV Export the displayed Events to a data file appropriate for importing into program like Excel. ("CSV" designates the "comma separated values" file format.)

Export PDF Save the displayed Events as a printable report in PDF format.

Filter Pane

Settings take effect when you click the **Search** button, at the bottom of the panel. The **Reset** button clears all filters.

Date and Time Filter

Shows only Events from the specified time period.

User and Device Filters

The display shows only the Events that match *all* the filters you specify. Note that the **Name** filters are case-insensitive, and will find partial matches. For instance, if you enter "john", the display will also show Events for "John", or "Johnny".

Event Type Filter

The display shows Events that match *any* of the Event Types you have checked. If nothing is checked, all Events are displayed.

Events Columns

See [Events](#).

▣ Related Topics

- [Reports and Printing](#)
- [System Settings](#)
- [Events](#)

2.8.10. ALARM HISTORY

Alarm History displays all Alarms, including resolved ones. Resolved Alarms are hidden in the [Alarms](#) screen. This view does not update in real-time or allow you to acknowledge or resolve Alarms.

Menu Buttons

Filter Opens a panel where you can define the kind of Alarms you wish to see. Settings take effect when you click the **Search** button, at the bottom of the panel. The **Reset** button clears all filters.

Date and Time Filter

Display Alarms from a range of dates and times.

User and Device Filters

The display shows only the Events that match *all* the filters you specify. Note that the **Name** filters are case-sensitive. For instance, if you enter "john," the display will not show Events for "John."

Event Type Filter

The display shows Alarms that match *any* of the Event Types you have checked. If nothing is checked, all Alarms are displayed.

Export PDF Save the displayed Alarms as a printable report in PDF format.

Alarms Columns

See [Alarms](#).

Related Topics

- [Reports and Printing](#)
- [Alarms](#)
- [Alarm Triggers](#)
- [Emergency Features](#)

The Access Control menu is primarily for determining who has physical access to Doors, when, and how.

You can also perform related tasks such as creating Users for Sentinel Series and creating [Door Mode Schedules](#).

Access to Doors

Create [Users](#) to provide door access to individual Users who use a credential such as a card and/or PIN. This is the most common door access method and allows you to track who comes and goes. You can simply give each User unrestricted 24/7 access to Doors, or further restrict their access using the following features.

Set up [Schedules](#) to allow access only at certain times, such as during business hours.

Create [Access Levels](#) to predefine a set of Doors and Schedules that can be quickly assigned to multiple Users.

Specify [Special Days](#) to restrict access more than usual for holidays, corporate events, or other days when access rules should differ. Special Days are used in Schedules.

Create [Shared Access Codes](#), which creates PIN codes that anyone can use to unlock designated Doors.

Special Features

The following features are used in special situations:

[Emergency Codes](#) are PIN codes that unlock Doors in an emergency.

Multi-User Access requires more than one User to present credentials to unlock sensitive areas. For example, a rule could be created such that three Users must present their card to open a Door.

[Door Mode Schedules](#) function like normal [Schedules](#) but are used in the [Doors](#) configuration to schedule Door Mode changes.

Access to Sentinel Series

Sentinel Series Users are added in the same [Users](#) configuration screen. A User can have both Door access and web application access.

3.1. USERS

Users can be created for the following purposes:

- Cardholders who can access Doors.
- Users who can [log in](#) to Sentinel Series.

A single User can have both Door and application access.

Menu Buttons

Filter Displays a panel above the list where you can search for a User on several properties. Users are displayed if they match *all* filters.

Settings take effect when you click the **Search** button, at the bottom of the panel. The **Reset** button clears all filters.

Import See [Importing Users from a CSV File](#).

Forgive Resets the selected User's anti-passback status. Use this when anti-passback rules are preventing a User's access, and this needs to be overridden.

Export All to CSV Exports all User (excluding the Admin User) to CSV file, in the same CSV format that is used for [Importing Users from a CSV File](#).

Key Properties

For the complete list and more details see [User Properties](#).

First Name and Last Name The User's first and last name. Both required, maximum 32 characters each.

Photo A photo of the User. This is shown here, and can be [printed on a card](#). To add or change the photo, click the photo image and select an image from your computer. Supported image formats are PNG, JPEG, and GIF.

Role	Cardholder Only for cardholder. The other Roles provide access to Sentinel Series. Each Role provides a different level of access; see User Roles . Users with the ability to log in also can have Door access.
Username and Password	If Role is not Cardholder Only , this is the username/password used to log in to the web application.
Cards	Add any number of cards that will be used for access. You can use a Card Enrollment Point to add a card number. Adding a card does not provide access; the User will also need Access Levels or Doors assigned, below.
PIN	PIN (Personal Identification Number) for the User, numeric only. Click Create New to generate a random, unique PIN. The length must match the PIN length defined in System Settings . (The default is 4 characters).
Access Levels, Door Access	<ul style="list-style-type: none">• Add Access Levels• Add access to individual Doors
Card Design	Use to print cards .

☰ Related Topics

- [User Properties](#)
- [User Roles](#)
- [Duress](#)
- [Access Levels](#)
- [Anti-Passback](#)

- [Printing Cards](#)
- [Card Enrollment Points](#)
- [System Settings](#)
- [Importing Users from a CSV File](#)
- [Logging In and Passwords](#)

3.1.1.1. USER PROPERTIES

The following are the properties available on the [Users](#) screen:

Identity

Status	Displays whether the current User's status is Valid or Invalid . The status will be Invalid if the current date is outside of the Valid To range, or if Disable User is checked.
First Name and Last Name	The User's first and last name. Both required, maximum 32 characters each.
Photo	A photo of the User. This is shown here, and can be printed on a card . To add or change the photo, click the photo image and select an image from your computer. Supported image formats are PNG, JPEG, and GIF.
Personnel ID	A unique identifier, such as an employee ID. Maximum 32 characters.
Role	Cardholder Only for cardholder. For Users with the ability to log in, select another Role. See User Roles . Users with the ability to log in also can have cards.

Language	<p>The User's preferred language, which will be</p> <ul style="list-style-type: none">• the User's default language in the Web Management Application, if they have the ability to log in, and• displayed on Doors that support multiple languages (such as some OSDP readers).
Valid From	<p>The date and time when access should begin. The default is the current date, at 00:00. This applies to both Door access and Sentinel Series login access.</p>
Until Further Notice, Valid To	<p>If Until Further Notice is checked, then the User's access is valid indefinitely. If it is unchecked, then the Valid To date and time must be provided, which determines when the User's access expires. This applies to both Door access and Sentinel Series login access.</p> <p>Note that the Valid To time takes effect at the end of the minute, not at the beginning.</p>
Disable User	<p>If checked, the User's access is disabled. This applies to both Door access and Sentinel Series login access.</p>
Vacation From, Vacation To	<p>If this date range is entered, it is a vacation date range during which the User's Door access is suspended. Sentinel Series login access is not affected by vacation dates.</p>

Login

The following properties only apply if **Role** is not **Cardholder Only**:

Username	<p>The username used to log in to the web application.</p>
Password	<p>The password used to log in to the web application. Passwords have minimum strength requirements.</p>

Additional Information

Email The User's email address. This is required for the User to receive system emails such as [Notifications](#).

Mobile Phone The User's mobile phone number.

Custom 1-4 Custom fields corresponding to those configured in [System Settings](#).

Access

Cards Click **Add** to add card numbers for Door access. Click **Enabled** to enable or disable a card. To enter a card number by swiping the card, see [Card Enrollment Points](#).

Each card has the following properties:

- **Type:**
 - **Standard:** A standard card. This is the default type.
- **Card Number:** the card number encoded within the credential, which uniquely identifies it.
- **Enabled:** if checked, the card is active. If unchecked, the card will be considered inactive, and denied access.

PIN	<p>The PIN (Personal Identification Number) used for Door access. Numeric only. The length must match the PIN length defined in System Settings (default is 4 characters).</p> <ul style="list-style-type: none">• PIN numbers must be unique, including Duress PIN codes, Shared Access Codes, and Emergency Access Codes.• Click Create New to generate a random unique PIN number.• Click Clear to clear the PIN.
Duress PIN	<p>The duress PIN generates a duress access Event when used in place of the normal PIN. Access is still granted if all other normal access conditions are met. See Duress for more details. For Duress PIN Type:</p> <ul style="list-style-type: none">• Select None if the Duress PIN is not used.• Select Add 1 to Last Digit to add one to the last digit, only, of the normal PIN. For example, a normal PIN of 1111 would then have a duress PIN of 1112, and a normal PIN of 9999 would have a duress PIN of 9990.• Select Explicit to enter an specific Duress PIN for this User. Numeric only. The length must match the PIN length defined in System Settings (default is 4 characters).
Access Levels	<p>Access Levels assigned to the User for Door access.</p>
Door Access	<p>Grants this User access to individual Doors during the selected Schedule. This is in addition to any Access Levels assigned.</p>
Use Extended Door Times	<p>If checked, extended unlock and held times are used when this User is granted access. This is for Users requiring additional time to get through a Door, for example a person with a disability. The amount of extra time is set on each Door.</p>

Important: Accessibility functions are regulated by country- and region-specific codes. Please refer to these when designing and configuring your system to ensure compliance.

Anti-passback Exempt	If checked, the User is not subject to anti-passback rules.
Access Doors in No Access Mode	If checked, the User can access Doors in No Access mode. This is typically only for administrators and security personnel.
Access Doors in Lockdown Mode	If checked, the User can access Doors in Lockdown mode. This is typically only for administrators and security personnel.
Allow First Credential Unlock	If checked, and the User access a door in a First Unlocks Door Mode, then the door will stay unlocked after the access. See First Credential Unlock for details.

Card Design

- Card Design Select a [card design](#). If selected, a preview is displayed.
- Click [Print Card](#) to print. When printing, if the card number is a part of the design, the card number must be selected.
- Click **Print Receipt** if the card is printed to a remote location, and the recipient must go pick it up.

Related Topics

- [User Roles](#)
- [Card Enrollment Points](#)

- [Access Levels](#)
- [Printing Cards](#)
- [Anti-Passback](#)
- [System Settings](#)
- [Logging In and Passwords](#)
- [Notifications](#)

3.1.2. PRINTING CARDS

You can print to a specialized printer that writes ID cards. You can also print a paper receipt for your use as a record or to authorize pickup at a remote printer.

To do either, you must first create [Card Designs](#).

To print, select a User, and:

1. Select a card design. (Your choice will be saved for this User.)
2. Click **Print Card** or **Print Receipt**.
3. Select a card number from the list.
4. Click **Print** and follow the prompts.

To complete the prompts, see [Reports and Printing](#).

▣ Related Topics

- [Users](#)
- [Card Designs](#)
- [Reports and Printing](#)

3.1.3. IMPORTING USERS FROM A CSV FILE

A CSV (comma-separated value) file can be add any number of Users using data from another software program. The other program must be able to export to CSV or a format you can convert to CSV. The CSV itself must be modified to exactly match the Sentinel Series import format using software such as a spreadsheet editor.

On the [Users](#) screen:

1. Click **Import**.
2. Click the link to download a template file that includes a header row with the column names pre-populated.
3. Review the import format, below.

In your own software:

4. Open the file, imported as UTF-8, with comma as the separator.
5. Create a copy of the file.
6. Modify the file, adding data for the users you want to create.
7. Save the file in CSV format, comma-delimited.
 - a. Make sure the file is in plain text and does not include any additional characters or encoding.
 - b. For example, if using any non-ASCII characters, the file must be encoded as UTF-8.

On the [Users](#) screen:

8. Click **Import**.
9. In the dialog, click **Import**.
10. Select the file from your computer. The file must have the ".csv" extension.
11. Click **Yes** to verify and import the file.
12. The number of imported Users is displayed. Click **OK**, and you will see the newly imported Users.

Import Format

File encoding must be UTF-8 (if using any non-ASCII characters), and the delimiter is comma.

Lines beginning with # are treated as comments, and ignored.

The header row, if present, should match exactly the column headers in the exported template.

The column values are defined as follows:

Column/Header	Type	Notes
First Name	Text	Required
Last Name	Text	Required
Personnel ID	Text	
Valid From	Date	See the note on accepted date formats.
Valid To	Date	See the note on accepted date formats.
Language	Text	This is a language code. See the language codes table below.
Email	Text	
Mobile Phone	Text	
Custom 1	Text	
Custom 2	Text	
Custom 3	Text	
Custom 4	Text	
User Enabled	Boolean	See the note on boolean values. Defaults to 1 (true).
Use Extended Door Times	Boolean	See the note on boolean values. Defaults to 0 (false).
Anti-passback Exempt	Boolean	See the note on boolean values. Defaults to 0 (false).
Card Number (1)	Number	
Card Enabled (1)	Boolean	See the note on boolean values. Defaults to 1 (true), if Card Number (1) is present.

Card Number (2)	Number	
Card Enabled (2)	Boolean	See the note on boolean values. Defaults to 1 (true), if Card Number (2) is present.
Card Number (3)	Number	
Card Enabled (3)	Boolean	See the note on boolean values. Defaults to 1 (true), if Card Number (3) is present.
Card Number (4)	Number	
Card Enabled (4)	Boolean	See the note on boolean values. Defaults to 1 (true), if Card Number (4) is present.
Card Number (5)	Number	
Card Enabled (5)	Boolean	See the note on boolean values. Defaults to 1 (true), if Card Number (5) is present.
Access Level (1)	Text	If specified, must match the name of an existing Access Level in the system
Access Level (2)	Text	If specified, must match the name of an existing Access Level in the system
Access Level (3)	Text	If specified, must match the name of an existing Access Level in the system
Access Level (4)	Text	If specified, must match the name of an existing Access Level in the system
Access Level (5)	Text	If specified, must match the name of an existing Access Level in the system

PIN

Number

May contain leading zeros

Dates should be in format YYYY-MM-DD or in the default format for the logged-in language (the language column in the CSV itself does not affect this):

- MM/DD/YYYY for English.
- DD/MM/YYYY for English (UK)/Spanish/French/Portuguese/Italian/Thai/Greek.
- DD.MM.YYYY for German/Turkish/Czech/Russian/Polish/Finnish/Norwegian.
- DD-MM-YYYY for Danish/Dutch.
- YYYY/MM/DD as well as the standard Chinese format with Chinese characters for Chinese.

Boolean fields use 0 for false; 1 for true.

Language codes:

Code	Language
en	English
en-GB	English (UK)
es	Spanish
es-ES	Spanish (Spain)
de	German
cs	Czech
da	Danish
el	Greek
fi	Finnish
fr	French

it	Italian
nl	Dutch
no	Norwegian
pl	Polish
pt	Portuguese
ru	Russian
sv	Swedish
zh	Chinese
zh-TW	Chinese (Traditional)
th	Thai
tr	Turkish
ro	Romanian
ja	Japanese
ko	Korean
ar	Arabic
hi	Hindi
he	Hebrew

☰ Related Topics

- [Users](#)
- [User Properties](#)

3.2. SHARED ACCESS CODES

A Shared Access Code is a PIN that multiple people can use to access specified Doors.

These codes only work when the current [Door Mode](#) allows a PIN by itself to open the Door. For example, PIN-Only or any mode that says "or PIN", such as "Card or PIN".

Shared Access Codes do not work with:

- Doors that are in Card-only mode, Card and PIN, etc.
- Doors with Multi-User Access rules (because a user group cannot be assigned to a shared access code).

Shared Access Codes are always exempt from [anti-passback](#).

Use of Shared Access Codes will impact the accuracy of a [Muster](#) report.

Shared Access Code Properties

Name	Required. Maximum 32 characters.
PIN	The Shared Access Code itself. Numeric only. Click Create New to generate a random, unique code.
Enabled	Checked to enable, unchecked to disable
Valid From	The date and time when access should begin. The default is the current date, at 00:00.
Until Further Notice, Valid To	If Until Further Notice is checked, then access is valid indefinitely for this Shared Access Code. If it is unchecked, then the Valid To date and time must be provided, which determines when access expires for the Shared Access Code. Note that the Valid To time takes effect at the end of the minute, not at the beginning.

Usage Limit	If a Usage Limit is specified, then the Shared Access Code may only be used that number of times. Only Access Granted transactions count as a "use".
Usage Count	If a Usage Limit is specified, then the Usage Count shows how many times the credential has been used so far. The Reset Usage button resets the usage count back to 0.
Description	Description or comments
Access Rights	<ul style="list-style-type: none"> • Add Access Levels, and/or • add Door Access entries to directly assign Door/Schedule pairs for access.

☰ Related Topics

- [Emergency Codes](#)
- [Access Levels](#)

3.3. EMERGENCY CODES

An Emergency Code is a PIN that allows access to Doors regardless of other settings, including the Door Mode. (Compare to [Shared Access Codes](#)). It is intended to be used by emergency and security personnel to gain access in emergency situations.

This means that an Emergency Code can access a Door which is under [Lockdown](#).

The successful use of an Emergency Code generates an Emergency Code Presented Event.

The Emergency Code Presented Event is configured as an [Alarm Trigger](#) by default, generating an [Alarm](#). The Emergency Code Presented Event can also be used as a Linkage to trigger the activation of an auxiliary output on the [Hardware](#) screen.

Emergency Codes are exempt from [anti-passback](#) and Multi-User Access. (Compare to [Shared Access Codes](#).)

Emergency Codes otherwise have the same properties as [Shared Access Codes](#).

Use of Emergency Codes will impact the accuracy of a [Muster](#) report for the emergency personnel who use them.

▣ Related Topics

- [Shared Access Codes](#)
- [Access Levels](#)
- [Emergency Features](#)

3.4. ACCESS LEVELS

An Access Level is a list of Doors, each paired with a Schedule, during which access is to be allowed.

Access Levels can be applied to [Users](#), [Shared Access Codes](#), and [Emergency Codes](#).

▣ Using the Screen

*On the left-hand side (**Select one or more items**):*

- Select the **Default Schedule to Use** when adding Doors to **Selected items**.
- Page through Doors using the arrows, and/or search by name.
- Select Doors to add them to **Selected items**.

*On the right-hand side (**Selected items**):*

- Change the **Schedule** for individual Doors using the drop-down.
- Select a Door to remove it from **Selected items**.
- Use **Change all assigned schedules** to change the schedule associated with all Doors in **Selected items**.

▣ Related Topics

- [Schedules](#)
- [Users](#)

- [Shared Access Codes](#)
- [Emergency Codes](#)

3.5. SCHEDULES

Schedules are used to limit access to certain days and times. They can be used in Access Levels and anywhere Door access is assigned.

By default, access is *not* allowed on [Special Days](#).

The built-in **24/7** Schedule allows access at all times, *including* Special Days.

Using the Screen

Access will be allowed during all the time periods you create. Click the **Add** and **Remove** buttons to add and remove time periods from the list.

Times (Start-Stop)	The left-side bar shows the time period access is allowed in green. You can drag the ends of the green bar to change the time range. You can also enter the exact times you want in the boxes under the bar. Times are entered and shown using a 24-hour clock (as opposed to "a.m". and "p.m.") Each bar can only have one time range; to have two time ranges on the same days, add another entry. The All day button is a convenience to reset the bar.
Days	The middle bar shows the days that access is allowed in green. You can click each day to change access, or you can use the convenience buttons to change the current selection. The convenience buttons are Weekdays , All days , and Weekend .
Special Days	The right bar appears green if you have included any Special Days for that time period. Click the bar to select Special Days to include. In the Special Days selection screen, you may check one or multiple Special Day types.

Access is normally denied on Special Days. Access will be allowed if you include the Special Days in the Schedule. For more information, see [Special Days](#).

▣ Related Topics

- [Special Days](#)

3.6. DOOR MODE SCHEDULES

Door Mode Schedules are used to change the mode of Doors at different times. For instance, they are commonly used to automatically unlock general-access Doors during business hours.

See [Door Modes](#) for a list of possible Door Modes.

Door Mode Schedules are assigned to Doors on the [Doors](#) screen.

A Door Mode Schedule can have multiple time intervals with different associated modes.

Note that emergency Door Modes cannot be scheduled.

▣ Using the Screen

Click the **Add** and **Remove** buttons to add and remove time periods from the list.

In the left column, select a single Door Mode. A Door will automatically change to this mode during the time period defined.

The time periods are defined the same way they are for Schedules. See [Schedules](#).

▣ Related Topics

- [Door Modes](#)
- [Special Days](#)
- [Schedules](#)

3.7. SPECIAL DAYS

Special Days are single calendar days (such as May 5th) which are excluded from Schedules by default. A Special Day is only included in a Schedule if the corresponding Special Day Type is selected withing the Schedule.

For a [Schedule](#) used for access, Users would be denied access by default on that day, even if access would otherwise be allowed based on the time of day, and day of week. If the Special Day Type is selected for that Schedule, those same Users would then have access on those days.

The same idea applies to [Door Mode Schedules](#). For any given interval, the selected Door Mode applies for the time of day and day of week, except for on Special Days - unless the corresponding Special Day Type(s) are selected.

Special Days are used for holidays, corporate events, and other cases where you do not want your usual access to be granted, or usual scheduled door modes to apply. For instance, you might use Access Mode Schedules to automatically unlock Doors during business hours Monday-Friday, but you do not want to do that on holidays.

▣ Special Day Types

Special Days are grouped into a number of Special Day Types. A type is essentially a calendar. For instance, one type might include all government holidays, while another might be teacher work days. You can then set different access rules for the different calendars.

Only Special Day Types can be added to a Schedule. So, you could add access on all government holidays, but not on a single one, unless you made a type with just that one day.

▣ Using the Screen

In the first section, **Special Day Types**, you can change the names of the types to something useful, such as "Government Holidays" or "Teacher Workdays". You may also change the color assigned to each type. The color has no effect except on this screen.

The second section, **Special Days**, shows a calendar highlighting all Special Days of all types in their color. To add or remove a day, click on it.

The two options above the calendar change what happens when you next click on a day. They cannot change the properties of current Special Days.

- **Select Special Day Type:** days added on the calendar will be this type. You cannot add days if no type is selected.
- **Set as Repeating:** when checked, days added on the calendar will be repeating. This means they will occur every year on the same calendar date. They are displayed with a small "R", and can be seen on every year.

Note that any single day can only be in one Special Day Type.

Related Topics

- [Schedules](#)
- [Door Mode Schedules](#)

4. CONFIGURATION

Use the Configuration menu to:

- Connect and configure hardware and Doors.
- Organize your hardware into locations and Areas, and plot it on Maps.
- Configure general settings for the [Monitor](#) and [Access Control](#) features.

Users with the System Administration [Role](#) can add and configure Controllers and Doors. Access Control Management Users can only configure Doors. Other built-in User Roles can do neither.

See [Administration](#) for configuring system settings such as the time or network connection.

Configuring Hardware and Doors

Before doing any configuration, it's important to read the brief topic, [Understanding Controllers and Doors](#). It is particularly useful for any Sentinel Series User to understand the definition of "Door" in the software.

[Hardware](#) is where the physical equipment (Controllers and their readers, inputs, and outputs) is added and configured. Hardware configuration is usually done by an expert who installs the system.

[Door configuration](#) is the starting point for all access control. Most importantly, this is where you specify if and when Doors are locked and how they can be opened. All [Access Control](#) settings are affected by Door configuration.

[Hardware Templates](#) and [Door Templates](#) can be used to quickly set up multiple Sub-controllers (I/O) or Doors with the same settings.

Organizing Hardware

[Locations](#) are labels that can be applied to Doors, Controllers, Maps, and other items. Locations appear in [Events](#) and [Alarms](#).

[Areas](#) are used with [anti-passback](#) and airlock. They define physical regions where you can restrict access using those features. The [Muster Report](#) also relies on Areas to determine whether each User is at a known, safe Area (Muster or Global Out).

You can also create [Maps](#) of your buildings and campus. Monitor these Maps to watch the live status of Doors and Controllers on an actual map of your facility.

General Settings

[Card Designs](#) allows you to create the print layouts for [Printing Cards](#).

[Card Formats](#) define the low-level details of how data is stored on the cards you use. Sentinel Series includes all of the card formats you will likely need. Use this screen to create a format for another type of card, or to enter a "facility code" as instructed by your card vendor.

Set up [Alarm Triggers](#) to define which Events trigger [Alarms](#).

4.1. UNDERSTANDING CONTROLLERS AND DOORS

▣ Controllers

▣ Sub-controllers (I/O)

Every Controller has a built-in [Sub-controller](#) (I/O). It is displayed under the Controller in Hardware with the additional label, "I/O", meaning "input/output". The Sub-controller manages the advanced details of the readers, inputs, and outputs of the hardware.

Additionally, separate physical Sub-controllers can be connected using RS-485/OSDP, to add additional I/O. See [Sub-Controllers](#) for supported models.

☰ Doors

A Door in Sentinel Series might represent one of many things:

- A real, physical door that can be entered
- A second reader that allows exit through a physical door. Notice that this means an [In/Out](#) physical door is represented by two Doors, one for "In", and one for "Out".
- Something that functions like a physical door, such as a turnstile or garage gate
- A reader by itself, with no physical door, used as a [Muster Point](#) or [Card Enrollment Point](#)

Doors are created on the [Hardware](#) screen, either automatically when the Controller is created, or by [customizing](#) the Controller.

☰ Related Topics

- [Hardware](#)
- [Sub-Controllers](#)
- [Doors](#)

4.2. HARDWARE

Hardware represents Controllers in Sentinel Series, including [Sub-controllers](#), Inputs, Outputs, and Readers. Door behavior, such as Door Mode or opening times, are configured in [Doors](#).

Hardware Topics

- [Models and Configurations](#)

- [Modifying Controller Configuration](#)
- [I/O Expansion Sub-Controllers](#)
- [Hardware Properties](#)
- [Adding Controllers](#)
- [Software Updates](#)
- [Resync All](#)

Related Topics

- [Doors](#)
- [Hardware Templates](#)

4.2.1. MODELS AND CONFIGURATIONS

Models

Model	Type	Wiegand Ports	RS-485 Slots	Number of "In" Doors	Max "Secondary" Doors	Default Reader Type	Default Type for Secondary Readers
ST200B	2-Door	4	OSDP	2	2	OSDP	OSDP
ST400B	4-Door	4	OSDP	4	4	OSDP	OSDP

In Doors are automatically created and are permanent, though they need not be used.

Secondary Doors are **Out Doors**, **Card Enrollment Points**, and **Muster Points**. The Readers of Secondary Doors are always paired with the Readers of In Doors in a defined way.

Controller Type	"In" to "Secondary"
-----------------	---------------------

	Reader Pairings
2-door	1 to 32 to 4
4-door	1 to 52 to 63 to 74 to 8

For example, on a 4-door Controller, Door 2 always uses reader #2 and is an **In** Door. If it has an **Out** Door, that Door will always use reader #6.

The reader number is not necessarily the same as its address. For Wiegand, the reader number *is* the same as the labels on the hardware, but any reader can be changed to use any available RS-485 address.

Notice that 4-door Controllers only have enough Wiegand reader ports for the **In** Doors. Any secondary Doors must use RS-485.

Configuration Property

The Configuration property of a Controller determines what the Controller's Doors will be used for: authorizing Door entry, perhaps Door exit, or as special purpose readers.

Configuration options available depend on the Controller model. Each option will involve one or more of the following possibilities. Each possibility determines the function of the Readers connected to the Controller.

- In Only** This the most common configuration, where a reader is used to gain entry, but no credentials are required to exit (although an exit button may be configured for opening the Door from the inside).
- In/Out** The physical door will have a reader both inside and outside. Authorization is required to pass either direction.
- + Muster Point** The second reader will serve as a [Muster Point](#), where Users can register that they have reached a safe location.

- + **Card Enrollment Point** The second reader will be used to easily enter card numbers when adding Users. See [Card Enrollment Points](#).

The available options do not cover all possibilities. For instance, 2- and 4-Door Controllers do not offer Muster Points or Enrollment Points as standard Configurations. To tailor the configuration to your needs, see [Modifying Controller Configuration](#). Modifying might be easier if you start with **In Only** as a baseline.

Related Topics

- [Adding Controllers](#)
- [Modifying Controller Configuration](#)

4.2.2. MODIFYING CONTROLLER CONFIGURATION

The **Modify** button on the menu bar is used to customize the [Configuration property](#) of a Controller. You will need to understand [Models and Configuration](#) to effectively customize a configuration.

Clicking **Modify** brings up a list of options. Some options will be disabled when they cannot be applied to the Controller as its readers are currently configured.

All options present a dialog to enter specifics for your change. The options are:

Change to Entry/Exit	Select the number of the Entry Access Point which will have an Exit Access Point paired with it.
Add Muster Point	Enter a Name for the new Access Point, and select the Entry Access Point number to pair it with.
Add Card Enrollment Point	Enter a Name for the new Access Point, and select the Entry Access Point number to pair it with.

Remove Secondary, Muster, or Card Enrollment Point	Select the number of the Entry Access Point that will have its paired Access Point removed.
Add Access Point (Monitor Open Only)	Reconfigure an available Input on an I/O Expansion Module to be a Monitor Open Only Access Point.
Remove Access Point (Monitor Open Only)	Remove a Monitor Open Only Access Point from an I/O Expansion Module , making the Input available as a general Input.
Add (I/O Expansion Sub-Controller)	Add an I/O Expansion Sub-Controller .

Related Topics

- [Models and Configuration](#)

4.2.3. HARDWARE PROPERTIES

The body of the Hardware screen allows Controller configuration and displays data about the Controller. Each Controller is represented by two components: (1) the Controller itself for general configuration, and (2) a Sub-controller (I/O) for detailed settings of readers, locks, door sensors, and other inputs and outputs.

Sub-controllers can be configured to a saved group of settings using [Hardware Templates](#).

Door behaviors, such as Door Modes and opening times, are configured in [Doors](#).

Controller Properties

Name	The name of the Controller. Required, maximum 32 characters.
Model	The model of the Controller.
Host Address	(Secondary Controllers only) IP address or hostname of the Controller.
Port	(Secondary Controllers only) Port number for the Controller.
Disconnected	<p>If checked, the Secondary Controller is treated as if it does not exist, and communication is not allowed. This cannot be checked on the Primary Controller.</p> <p>This can be useful during the installation or maintenance of hardware.</p>
Status	Displays the current status of the device, including Online/Offline. If any tamper, power, or battery problems are present, these will be indicated here as well. Lockdown or Emergency Unlock will be indicated here, when active.
Serial Number	The serial number of the Controller. This is displayed only if the device is online.
Software Version	The software version of the Controller. This is displayed only if the device is online.
Configuration	See Models and Configuration .
Location	The Location of the Controller.
Description	Description or comments

Language	<p>Sets the default language for</p> <ul style="list-style-type: none">• Sentinel Series on the Primary Controller,• the simplified management application on a Secondary Controller, and• multi-language OSDP readers connected to this Controller, if they have displays. <p>Available languages depend on your software license.</p>
Time Zone	(Secondary Controllers only) The time zone of the Secondary Controller.
Managed Doors	A list of the Doors managed by the Controller, with links to their configuration screens .
Managed Sub-controllers	A list of Sub-controllers managed by this Controller, with links to their hardware configuration.
Software Update	(Secondary Controllers only) Update the software on a Controller.
Open Web Page	Click the link to log in directly to a Secondary Controller. You will enter a simplified web management application allowing limited Controller configuration options.
Reboot Button	(Secondary Controllers only) Reboots the Controller
Resync Button	(Secondary Controllers only) Refreshes the configuration of this Secondary Controller.

Sub-controller (I/O) Properties

Name	(Read-only) The name of the Sub-controller.
Disconnected	(Read-only) Always unchecked and cannot be changed.
Status	(Read-only) Always Online for Sentinel Series built-in Sub-controllers.
Model	(Read-only) The device model.
Description	Description or comments
Hardware Template	<p>Select an existing template and click Apply Template. Deselect Apply Template to edit the settings.</p> <p>Click Create Hardware Template to create a new template from the current settings. The template contains most of the Sub-controller configuration. See Hardware Templates.</p>

Reader Properties

Address	If Wiegand, the address label printed on the Controller. Otherwise, Address is the address label which this reader replaces, or a virtual address which is above those printed on the board.
Managed By	The Door that the device is associated with
Model	<p>The device model:</p> <ul style="list-style-type: none"> • Custom — for Wiegand or OSDP readers
Reader Type	<ul style="list-style-type: none"> • Data0/Data1 (Wiegand) • OSDP — for model Custom

- Keypad Type** For **Data0/Data1 (Wiegand)** readers only.
- If Auto, then PIN digits are accepted over Wiegand, automatically decoding the format.
 - **None** is displayed for no PIN pad. (It generally makes sense to leave this on Auto, unless you want to specifically disable a PIN pad on a Wiegand reader.)
- Tamper** The type of tamper detection. Only **OSDP** is supported on OSDP readers.
- LED Type** The LED control type:
- For Wiegand, this is either:
 - **None** — select this to disable LED control completely
 - **1-Wire (Green)** — one wire wired to the green LED (red LED generally lit when green is not)
 - **2-Wire (Red and Green)**
 - For OSDP readers, this is **OSDP**.
- Serial Port** For OSDP/RS-485 Readers, the serial port the Reader is connected to.
- OSDP/RS-485 Address** The "polling address" of the OSDP or RS-485 reader.
- For most OSDP readers the default is 0. See **Configure**, below, and installation instructions from the reader manufacturer, for how to change the address.
- Configure** **Configure** opens the OSDP Configuration Wizard, which can be used to:
- Change the OSDP address that the reader itself is configured to use. This is *not* the **OSDP/RS-485 Address** the Sub-controller is set to use, though they must ultimately have the same value.

- Manage the encryption key used to communicate with the reader.

See [OSDP Devices](#) for more details.

Input Properties

Address	The printed address on the board.
Name	The name of the input. Required, maximum 32 characters.
Enabled	Check to enable, uncheck to disable.
Normally Open	Whether the input is normally open (NO). Normally open inputs are active when the wires are normally not connected (open circuit). This is generally true for exit buttons. Most other inputs like tamper, power, and battery failure sensors are normally closed (NC).
Function	What the input is used for. Not all options are available for all inputs, and some cannot be changed. The Functions are: <ul style="list-style-type: none">• Exit Button• Door Sensor• Tamper• Power Monitor• Battery Monitor• Linkage• Not Used
Managed By	For exit buttons and door sensors, this is the Door that the input is a part of. For tamper, power monitor, and battery monitors, this is the

Controller they are a part of. For Linkage inputs, this is the device affected by the linkage. (See **Linkage Type**.)

"Out" Doors cannot be used in linkages, nor to manage hardware.

Linkage Type For **Linkage** inputs, this is an action to be performed when the input becomes active. The options depend on the **Managed By** setting

- **Input-Triggered Alarm** (Managed By: empty) — This will cause an [Alarm](#) to be generated when the input becomes active. Do not confuse this with a relay activating an audible alarm, which can be configured for an output, below.
- **Input-Triggered Lockdown** (Managed By: a Controller) — When the input is activated, a [Global Lockdown](#) is initiated. The lockdown will only end when a User clicks **Clear Lockdown** on the [Main Menu](#) (with some exceptions*).
- **Input-Driven Emergency Unlock** (Managed By: a Controller) — Whenever the input is active, a Global Emergency Unlock condition will be active. The emergency unlock will only end when the input returns to inactive (with some exceptions*).
- **Input-Triggered Momentary Unlock** (Managed By: a Door) — This will cause a momentary unlock of the Door when the input becomes active.

***Important:** As with all emergency functions, you should thoroughly understand the [relevant topics](#) before relying on lockdown and emergency unlock.

Schedule (Linkage only) If a Schedule is selected here, the **Linkage** will only be applied during this Schedule.

Output Properties

Address The printed address on the board.

Name	The name of the output. Required, maximum 32 characters.
Function	What the output is used for: Not all options are available for all outputs, and not all can be changed. The options are: <ul style="list-style-type: none">• Reader Beeper• Reader LED (Green)• Reader LED (Red)• Lock• Linkage• Not Used
Managed By	For Lock, Reader Beeper, and LEDs this is the Door they are used for. For Linkage, this is the device whose Events can trigger this output. "Out" Doors cannot be used in linkages, nor to manage hardware.
Event / Condition	(Linkage only) Defines the Event or condition that triggers an output. Controller triggers: <ul style="list-style-type: none">• Tamper Door triggers: <ul style="list-style-type: none">• Access Denied• Access Granted• Door Forced Open• Door Held Open• Duress• Emergency Code Presented

Input triggers:

- **Input Active**

Triggers when **Managed By** is blank:

- **Schedule Active**

Toggle / Pulse (**Linkage** only) If **Pulse**, the Event activates this output briefly. If **Toggle**, this output is active until the Event is "ended" by its reverse Event. For example, "Door Held Open" is reversed by "Door Held Open Restored". **Toggle** is not an option when the Event has no reverse Event.

Pulse Time (**Linkage** only) The pulse time in seconds.

Schedule (**Linkage** only) If a Schedule is selected here, the **Linkage** will only be applied during this Schedule.

▣ Related Topics

- [Understanding Controllers and Doors](#)
- [Hardware Templates](#)
- [Models and Configuration](#)
- [Locations](#)
- [Doors](#)

4.2.4. ADDING CONTROLLERS

Manually Adding a Secondary Controller

To add a Controller:

1. Click **Create** on the menu bar. The create controller screen will appear.
2. Select a [Model](#).
3. Select a [Configuration](#).
4. Enter a **Name**, and select **Custom Door Names** so you can name the doors in the box, below.

Replacing a Secondary Controller

If you need to replace a Secondary Controller, you can transfer all of its configuration to the new Controller.

The new Controller must be the same model as the original Controller.

To replace a Secondary Controller:

1. Physically disconnect or turn off the original Secondary. Replacement will not work while it is active. *Do not disconnect or delete it on the Hardware screen.*
2. If the new Controller has been used before, perform a [Factory Reset](#) on that Controller.
3. Completely install the new Controller according to the instructions that came with it. Do complete the [Installation](#) for a Secondary as usual (see the note, below).
4. Select the original Secondary on the Hardware screen.
5. Click the **Replace** button at the bottom of the properties, and confirm in the next window. You should see a message indicating that Replace has started.
- 6.

The Status of the Secondary should change to **Online** shortly.

Related Topics

- [Models and Configuration](#)
- [Modifying Controller Configuration](#)

Related Topics

- [Hardware](#)

4.2.6. RESYNC ALL

The **Resync All** button on the menu bar causes a full resynchronization of data to all Secondary Controllers. All configuration from Sentinel Series (on the Primary Controller) is freshly updated on all Secondary Controllers. This includes all hardware, Door, and access configuration, including Users data. It does not include Network or Software version settings.

Individual Secondary Controllers can be resynchronized under **Maintenance** on their [Hardware](#) pages.

4.2.7. I/O EXPANSION SUB-CONTROLLERS

I/O expansion Sub-Controllers provide additional I/O and capabilities for Controllers.

Sub-Controllers are added through the **Modify** menu, with a given selected Controller, in the **Hardware** screen.

Sub-Controllers can be monitored in [Sub-Controller Status](#).

Sub-Controller models:

- [AHEB-0808](#)

Related Topics

- [Adding Controllers](#)
- [Modifying Controller Configuration](#)

4.2.7.1. AHEB-0808

The AHEB-0808 I/O Expansion Board is connected to a Primary or Secondary Controller via RS-485/OSDP, and adds 8 Inputs and 8 Outputs.

The baud rate for the RS-485/OSDP connection is 9600.

The 8 inputs are supervised, with 1K/2K supervision.

The inputs and outputs can be used for linkages, very similarly to built-in I/O Sub-controllers.

The AHEB-0808 does not support Wiegand or OSDP readers, but it can be used for Monitor Open Only Doors. A Monitor Open Only Door is a door with only a Door Sensor. When such a Door is being monitored, events and status are reported very similarly to Forced Open monitoring on a standard Door.

This monitoring can be masked or unmasked, both manually or according to a schedule. These doors also monitor for the Held Open condition, which can be similarly masked.

This type of Door is useful in situations where certain doors are not supposed to be opened at certain times, but, full electronic access control with a reader is not installed on them.

Adding an I/O Expansion Board

1. Navigate to [Hardware](#) and select the Primary or Secondary Controller.
2. Press the **Modify** button and choose **Add AHEB-0808**
3. Enter a **Name** of your choosing.
4. For **Serial Port**, select **COM1**.
5. For **OSDP Address**, select the OSDP address that corresponds to the DIP switches on the device. This address is from 0-15, and corresponds to DIP switches **AD1, AD2, AD3, AD4**.
6. Press **Add**
7. When the Sub-controller comes online, its status will be shown as Online here, as well as in [Sub-Controller Status](#)

Adding a Monitor Open Only Door

1. Navigate to [Hardware](#) and select the AHEB-0808.
2. Press the **Modify** button and select **Add Door (Monitor Open Only)**
3. Enter a **Name** of your choosing.

4. Select the **Input** which is to be used to monitor the Door
5. Press the **Add** button.
6. The status of the Door can be monitored in [Door Status](#)

Monitoring I/O Expansion Board Status

AHEB-0808 I/O Expansion Boards are Sub-Controllers, and therefore can be monitored in [Sub-Controller Status](#).

Related Topics

- [Hardware](#)
- [Door Status](#)
- [Sub-Controller Status](#)
- [Manual Commands](#)

4.3. DOORS

A Door represents a device which electronically controls physical access (see [Understanding Controllers and Doors](#)).

Doors are automatically created to match the **Configuration** property of Controllers in [Hardware](#).

Menu Buttons

Manual Commands	Allows direct control of the selected Door using Manual Commands to change Door Mode or unlock the Door.
------------------------	--

Key Properties

For the complete list and details, see [Door Properties](#).

Name	The name of the Door. Required, maximum 32 characters.
Type	Shows the Door's function: In , Out , Card Enrollment Point , or Muster Point . This is determined in Hardware .
Door Template	Used to configure this Door with a template , which overrides and disables some properties on this screen.
Default Mode	The Door Mode for this Door whenever not altered by a Schedule, manual command, or Event. Door Mode determines whether a Door is locked, and what kinds of access can unlock it.
Door Mode Schedule	Pick a Door Mode Schedule to change the Door Mode according to the time of day, day of week, and Special Days .
Multi-User Access	See Multi-User Access.
Areas and Anti-passback	See Areas .

▣ Related Topics

- [Door Properties](#)
- [Door Modes](#)
- [Door Templates](#)
- [Manual Commands](#)
- [Door Status](#)

4.3.1. DOOR PROPERTIES

Door properties differ based on the door type. For example, Muster and Card Enrollment Points have far fewer properties since they do not control a door strike or have other door hardware.

Name	The name of the Door. Required, maximum 32 characters.
Status	The current status of the Door, including online/offline, Door Mode , locked/unlocked, open/closed, or errors such as forced, held, tamper, reader offline. Lockdown or Emergency Unlock will be indicated here, when active.
Alarm	If any Alarm is pending at the Door, it is shown here.
Type	How the Door is used: <ul style="list-style-type: none">• In — an entry Door. Either an entry-only Door, or an entry Door as a part of an entry/exit (in/out) Door pair.• Out — an exit Door.• Muster Point — used to check in during an emergency for the Muster report.• Card Enrollment Point — used only to enroll cards.
Controller	The Controller that this Door is managed by.
Sub-Controller	The Sub-controller (I/O) which manages this Door's hardware.
Door Template	A Door Template defines common parameters. Once a Door is linked to the template, the fields are read-only in the Door screen. If the Door template is modified, the associated Doors are also updated.

Location	Location of the Door.
Description	Description or comments
Default Mode	The Door Mode for this Door whenever not altered by a Schedule, Manual Command, or Event. Door Mode determines whether a Door is locked, and what kinds of access can unlock it.
Door Mode Schedule	Pick a Door Mode Schedule to change the Door Mode according to the time of day, day of week, and Special Days .
Multi-User Access	The Multi-User Access configuration, if multiple Users are required to open a Door.
Unlock Time (s)	The amount of time the lock is activated for an access (access granted, exit requested, etc).
Default Forced Open Masking	<ul style="list-style-type: none"> • Default - Unmasked • Unmasked • Masked
Forced Open Masking Schedule	If selected, Forced Open will be masked during the selected Schedule .
Default Held Open Masking	<ul style="list-style-type: none"> • Default - Unmasked • Unmasked • Masked

Held Open Masking Schedule	If selected, Held Open will be masked during the selected Schedule .
Default Monitored Open Masking	Only applicable to Monitor Open Only Doors: <ul style="list-style-type: none">• Default - Unmasked• Unmasked• Masked
Monitored Open Masking Schedule	If selected, Monitored Open will be masked during the selected Schedule . Only applicable to Monitor Open Only Doors.
Held Open Alarm Time (s)	The amount of time a Door can be held open before a held open Event is generated. This Event can be configured in the Sub-controller configuration to drive an aux output, for example, to sound a beeper.
Minimum Unlock Time (s)	If Re-lock On allows for the Door to be re-locked before the strike time is up, then this is the minimum time the Door will stay unlocked. This is to avoid an unlock pulse that is too brief, which can be a problem for some hardware.
Extended Unlock Time (s)	If a User has Use Extended Door Times checked, this time is used instead of Unlock Time . Important: Accessibility functions are regulated by country- and region-specific codes. Please refer to these when designing and configuring your system to ensure compliance.

Extended Held Time (s)	<p>If a User has Use Extended Door Times checked, this time is used instead of Held Open Alarm Time.</p> <p>Important: Accessibility functions are regulated by country- and region-specific codes. Please refer to these when designing and configuring your system to ensure compliance.</p>
Held Open Pre-Alarm Warning Time (s)	<p>The amount of time before the Held Open Alarm Time is reached, when a held open pre-alarm warning Event is generated.</p> <p>This Event can be configured in the Sub-controller configuration to drive an aux output, for example, to sound a beeper.</p>
Suppress Exit Button Events	<p>When selected, exit requested Events are not created for this Door. This can be used if the number of these Events is considered too numerous and unimportant.</p>
Unlock on Exit Button	<p>If checked, the Door is unlocked when the exit button is pressed. This may not be required for systems where the exit button is wired directly to cut off power to the lock, for example.</p> <p>Important: Exit button functions are regulated by country- and region-specific fire codes. Please refer to these when designing and configuring your system to ensure compliance.</p>
Re-lock On	<p>When the lock should be re-locked after access is granted:</p> <ul style="list-style-type: none">• End of Unlock Time• Door Open• Door Close• Door Close or End of Unlock Time (whichever is sooner)

Exempt From Global Lock-down	If checked, the Door will not be affected by a global lockdown
Exempt From Global Emergency Unlock	If checked, the Door will not be affected by a global emergency unlock
Entering Area	The Area the Door leads into for anti-passback (and airlock) configurations.
Exiting Area	The Area the Door leads out of for anti-passback (and airlock) configurations.
Anti-passback Method	<ul style="list-style-type: none">• None — no anti-passback enforced• Door-Based — cannot use same credential within certain amount of time at the same Door.• Area-Based — checks that they are known to be in the correct Area before using a Door leading out of that Area, into another Area. See Anti-Passback .
Anti-passback Mode	Available if Anti-passback Method is Area-Based : whether to deny or grant access on an anti-passback violation: <ul style="list-style-type: none">• Hard (Deny Access)• Soft (Grant Access)
Minutes Denied	Available if Anti-passback Method is Door-Based . The number of minutes before the same credential can be used at the Door. If blank, a default of 60 minutes is used.

Related Topics

- [Doors](#)
- [Door Templates](#)
- [Door Status](#)
- [Door Modes](#)
- [Anti-Passback](#)
- [Manual Commands](#)
- [Hardware Properties](#)
- [Locations](#)
- [Areas](#)

4.4. LOCATIONS

Locations are labels you can apply to organize Doors and hardware on lists and reports, particularly on [Events](#) and [Alarms](#). Locations can be assigned to [Doors](#), [Controllers](#), [Areas](#), and [Maps](#).

Location Properties

Name The name of the Location. Required, maximum 32 characters.

Type Category by Location size. From large to small, they are:

Region > Campus > Building > Floor > Room

Parent Location Designates this Location as included in any *larger* Location. A **Building's** parent could be a **Campus** or **Region**, but not a **Floor** or **Room**.

When you filter Events to a Location, all the smaller Locations that are included in it will also be displayed.

▣ Related Topics

- [Events](#)
- [Alarms](#)

4.5. AREAS

Areas are physical regions you define, and are used for [Anti-Passback](#), [Muster](#), and airlocks. A column to show the Area can be added on [Events](#) and [Alarms](#).

Areas are actually nothing but a label. They serve no function until you define which Doors lead into and out of the Area. You do this by setting the **Entering Area** and **Exiting Area** of each relevant [Door](#).

▣ Predefined Areas

There are two Areas that are predefined by the system and cannot be edited or deleted:

- **Global Out** — Doors that enter from, or exit to, the “outside world” should use this as the **Exit Area** or **Entry Area**, respectively.
- **Muster** — An Area where all [Muster Points](#) “enter” to. Anyone who uses a Muster Point will have their last known Area set to the Muster Area and will be excluded from the Muster report.

▣ Using the Screen

Name The name of the Area. Required, maximum 32 characters.

Location A [Location](#) to associate with the Area

Type • **Local** — Used only on a single Controller. Can be used for airlock.

- **Global** — Can be used on multiple Controllers, for global [anti-pass-back](#) enforcement.

Managed By (Local Areas only) The single Controller for this Area.

Airlock Mode (Local Areas only)

- **No Exit During Entry** — A Door exiting the Area cannot be used while a Door entering the Area is open.
- **Strict Single Door** — No two Doors in the Area can be unlocked/opened at the same time.

Description Description or comments

Related Topics

- [Anti-Passback](#)
- [Muster](#)

4.6. MAPS

Maps configuration is used to create the screens for the [Maps view](#).

The Maps view is used to show the status of your Doors and Controllers on graphical backgrounds, for example, on maps of your building or campus. It highlights all problems in red, and allows sending commands to Doors. Maps may also have links to other Maps for easy navigation.

Map Properties and Controls

Name The name of the Map (required, maximum 32 characters)

- Location** Optional [Location](#) of the Map.
- Background** Click **Upload** to load an image from your computer. This will be the canvas on which you can place devices. Large images will shrink to fit the available space.
- Elements** Elements, in multiple list boxes, can be clicked on and dragged to the Map.
- These elements can be:
- **Custom Elements**
 - **Hardware** (Controllers)
 - **Doors**
- When on the Map, their blue wrench icon provides options to
- delete the element, or
 - set the destination of a "Link" element from a list of other Maps.
- Text entered in **search** filters all three element lists.

▣ Related Topics

- [Maps \(Monitoring\)](#)

4.7. CARD DESIGNS

A Card Design is a print layout you create for use in [Printing Cards](#). It can include User information such as the name and expiration date and images such as the User photo and logos.

Properties

Name The name of the Card Design. Required, maximum 32 characters.

Description Description or comments.

The Design Area

Center Column

The center area is your canvas to "draw" your card on. It shows a standard size access card, front and back sides.

Important: Review your card printer manual to understand its limitations, such as whether it can print both front and back and whether you are allowed to print to the edge of the card.

Left Column

Click and drag elements from the left panels onto the card area.

Click elements on the card area to select them. Shift-click to select multiple elements.

Drag selected elements to move them.

Images (only) can be sized by dragging on the corners.

Right Column

The first row of three icons performs standard delete, undo, and redo actions.

The second row has six options for aligning elements, followed by four options controlling which elements are on top of others. Hover over any icon to see its exact function. You must select more than one item to enable the alignment options.

The rest of this panel shows the properties of the currently selected item.

For **Images**, click **Select Image** to load an image file from your computer.

For **Text** and **User Fields**, enter the **Text**. Text between "{" and "}" will be replaced with the named property of the User. Additional text may be added outside the brackets, but the text inside must be a valid field name.

The remaining options for text set the font and color.

X Origin and **Y Origin** are properties of both images and text. They determine which direction the element will grow to fit the contents, *by choosing which corner will never move*. The default is top left, and the box will expand to the right and down when, for instance, the name field is long or its font size increases. If you change the origin to bottom right, the box will expand upwards and to the left, allowing you to place the box on the right or bottom edge of the card.

Notes

Supported image formats are PNG, JPEG, and GIF.

Text will print over of images (if on top), and transparency in images is supported.

Related Topics

- [Users](#)
- [Printing Cards](#)

4.8. CARD FORMATS

Card Formats define the low-level details of how data is stored on the cards you use. Sentinel Series includes all of the card formats you will likely need, although you might want to enter a "facility code" specified by your card vendor.

If you do use an uncommon type of card, you will have to create a custom card format. This is quite technical, and requires exact specifications from the card vendor.

Notes

You can use more than one card format in your system.

Card formats are neither associated with specific Doors nor specific Users—they all are used for all.

Two card formats with the same number of bits cannot be enabled at the same time, unless they both have facility codes and those codes are different.

Entering Your Facility Code

You must know which of the existing card formats matches your cards. Simply select that format, enter the **Facility Code** number, and save.

▣ Card Format Properties

Note: Start and location fields are number of the bit, where the first bit on the card is number 0.

Name	The format name. Required, maximum 32 characters.
Bits	The total number of bits on the card, including parity bits, etc.
Enabled	Use or do not use the format.
Facility Code	(optional) If there is a facility code field (start/length specified), this is the value that the facility code must be equal to for the format to be matched.
Facility Code Start	The facility code start (bit number).
Facility Code Length	The facility code length (in bits).
Card Num Start	The card number start (bit number).
Card Num Length	The card number length (in bits).
Parity (1-4)	<ul style="list-style-type: none"> • None/Even/Odd — None to not use this parity field at all, Even or Odd for parity calculation method. • Start — The start bit of the parity source (the range of bits to be checked for parity). Does NOT include the location of the parity bit itself. • Length — The length in bits of the parity source. • Location — The bit number of the parity bit. • Mask — Normally, the entire source is used. If only some bits in a pattern are to be used in the source, this is entered here as the mask, as a string of 0s and 1s.

4.9. ALARM TRIGGERS

[Alarms](#) are triggered by Events, meaning that whenever an Event of a specified [type](#) occurs, an Alarm is also generated. The Alarm Triggers screen allows you to add to the Events that trigger Alarms and modify or remove the default triggers.

Alarm Trigger Properties

Triggering Event The Event Type which will trigger an Alarm.

Priority The importance of the Alarm created. The **Priority** can be used to sort the Alarms screen.

Color Triggering Event The triggering Event will be in this color on the [Events](#) screen. This does not affect the Alarm color. (Some Event Types also have a color, whether or not they are Alarm triggers.)

Auto-acknowledge If checked, the triggered Alarm will start off in the **Acknowledged** state.

Related Topics

- [Alarms](#)
- [Events](#)
- [Event Categories and Types](#)
- [Emergency Features](#)

4.10. DOOR TEMPLATES

Door Templates can be created from existing Door configurations, then applied to other Doors that require the same settings. Subsequent changes to the template are applied to every Door using it. Only certain Door properties are controlled by the Template (see below).

When a Door Template is applied to a Door, the properties which come from the template are no longer editable on the Doors screen. To change them, you must either edit the template, or remove the template from the Door.

A Door Template cannot be applied to a Door that has a different **Type** in its [Door properties](#).

■ Creating a Door Template from an Existing Door

1. Go to the [Doors](#) screen.
2. Select a Door.
3. Click the **Create Door Template** button in the Door's properties.
4. Enter a name (required, maximum 32 characters), and optionally, a description.
5. Click **Save**.

■ Applying a Door Template to a Door

1. Go to the [Doors](#) screen.
2. Select a Door.
3. Select a **Door Template** in the Door's properties.
4. Check **Apply Template**. The Door will use the settings from the template only when this is checked. If you remove the check, the Door will keep the template settings unless you change them.
5. Click **Save**.

■ Door Template Properties

A Door Template overrides these [Door Properties](#). Some Door types do not use all of these properties.

- **Manual Commands Enabled**
- **Unlock Time**

- **Held Open Alarm Time**
- **Minimum Unlock Time**
- **Extended Unlock Time**
- **Extended Held Time**
- **Held Open Pre-Alarm Warning Time**
- **Suppress Exit Button Events**
- **Unlock on Exit Button**
- **Re-lock On**

☰ Related Topics

- [Doors](#)
- [Hardware Templates](#)

4.11. HARDWARE TEMPLATES

Hardware Templates can be created from existing Sub-controller (I/O) properties, then applied to other Sub-controllers that require the same settings. Subsequent changes to the template are applied to every Sub-controller using it. Only certain Sub-controller properties are controlled by the Template.

When a Hardware Template is applied to a Sub-controller, the properties which come from the template are no longer editable on the Sub-controller screen. To change them, you must either edit the template, or remove the template from the Sub-controller.

☰ Creating a Hardware Template from an Existing Sub-controller

1. Go to the [Hardware](#) screen.
2. Select a Sub-controller.
3. Click the **Create Hardware Template** button in the Sub-controller's properties.

4. Enter a name (required, maximum 32 characters), and optionally, a description.
5. Click **Save**.

▣ Applying a Hardware Template to a Sub-controller

1. Go to the [Hardware](#) screen.
2. Select a Sub-controller.
3. Select a **Hardware Template** in the Sub-controller's properties.
4. Check **Apply Template**. The Sub-controller will use the settings from the template only when this is checked. If you remove the check, the Sub-controller will keep the template settings unless you change them.
5. Click **Save**.

▣ Related Topics

- [Hardware](#)
- [Door Templates](#)

5. ADMINISTRATION

The Admin menu includes a variety of settings for the whole system.

[User Roles](#) lets you see the definition of the built-in User Roles for Users logging into the web application and define new, custom roles.

[System Settings](#) provides control over the custom field labels.

5.1. USER ROLES

User Roles define what different Users can do within Sentinel Series. The system comes with a number of built-in User Roles which may not be modified or deleted. Custom User Roles can be created.

Here is a summary of the built-in User Roles.

System Administration	Unlimited; able to access all screens and functions.
Access Control Management	Provide access to Users and define the Doors, times, and other access control rules that allow or deny access. Able to configure Doors, but not Hardware. Able to execute all manual commands.
Basic Monitoring	Most monitoring functions. Able to view Alarms but not acknowledge or resolve them. Able to view Users but not create or edit them.
User and Credential Management	Add and manage Users and their associated credentials. Also able to perform some limited monitoring tasks. No Alarm management, and no hardware or Door configuration.
Alarm Monitoring	Similar to Basic Monitoring, but also able to acknowledge and resolve Alarms.

▣ User Role Options - Menu Items

Option	System Administration	Access Control Management	Basic Monitoring	User and Credential Management	Alarm Monitoring
About: License	Yes				
Access Control: Access Levels	Yes	Yes			
Access Control: Door Mode Schedules	Yes	Yes			
Access Control: Emergency Codes	Yes	Yes			

Access Control: Multi-User Access	Yes	Yes			Yes	
Access Control: Schedules	Yes	Yes				
Access Control: Shared Access Codes	Yes	Yes			Yes	
Access Control: Special Days	Yes	Yes				
Access Control: Users	Yes	Yes			Yes	
Access Control: Users (Read-Only)	Yes	Yes	Yes	Yes	Yes	Yes
Administration: Archive Downloads	Yes					
Administration: Backup and Restore	Yes					
Administration: Communications	Yes					
Administration: Date and Time	Yes					
Administration: Email Settings	Yes					
Administration: Software Settings	Yes					
Administration: Network	Yes					
Administration: System Settings	Yes					
Administration: User Roles	Yes					

Monitoring: Reports: Access Levels	Yes	Yes				
Monitoring: Alarm History	Yes		Yes			
Monitoring: Reports: Audits	Yes	Yes				Yes
Monitoring: Reports: Doors	Yes	Yes				
Monitoring: Reports: Event History	Yes	Yes	Yes	Yes		Yes
Monitoring: Reports: Muster	Yes	Yes	Yes	Yes		Yes
Monitoring: Reports: Schedules	Yes					
Monitoring: Reports: Users	Yes	Yes	Yes	Yes		Yes
Monitoring: Reports: Users With Access Level	Yes	Yes	Yes	Yes		Yes
Monitoring: Reports: Users With Access to Door	Yes	Yes	Yes	Yes		Yes

☐ User Role Options - Manual Commands

Option	System Administration	Access Control Management	Basic Monitoring	User and Credential Management	Alarm Monitoring
Controller: Software Update	Yes				
Controller: Reboot	Yes				

Controller: Replace	Yes					
Controller: Resync	Yes					
Credential: Reset	Yes	Yes	Yes	Yes	Yes	Yes
Door: Momentary Access	Yes	Yes	Yes	Yes	Yes	Yes
Door: Set Door Mode	Yes	Yes				Yes
User: Forgive	Yes	Yes	Yes	Yes	Yes	Yes

User Role Options - Door Modes

Option	System Administration	Access Control Management	Basic Monitoring	User and Credential Management	Alarm Monitoring
Cancel/Clear	Yes	Yes			Yes
Unlocked	Yes	Yes			Yes
No Access	Yes	Yes			Yes
Card Only	Yes	Yes			
Card and PIN	Yes	Yes			
PIN Only	Yes	Yes			
Card or PIN	Yes	Yes			
Unlocked (Emergency)	Yes	Yes			Yes
Lockdown	Yes	Yes			Yes
Card Only (First Unlocks)	Yes	Yes			
No Access, No Exit Button	Yes	Yes			Yes
Card and PIN (First Unlocks)	Yes	Yes			

PIN Only (First Unlocks)

Yes Yes

Card or PIN (First Unlocks)

Yes Yes

Related Topics

- [Users](#)

5.2. SYSTEM SETTINGS

System settings define assorted settings used by the system, for database maintenance, custom fields, and PIN length.

Custom Fields

This section allows you to change the custom field labels which appear in the [Users](#) screen. Maximum 32 characters.

Shared Access/Emergency/PIN Codes

This section allows you to change the system-wide length of all [Shared Access Codes](#), [Emergency Codes](#), and PIN Codes ([Users](#) screen). The same length is used for all of these.

Changing the length will alter all existing PINs.

- Increasing PIN length will prepend zeros to existing shared access codes, emergency codes, and User PIN codes.
- Decreasing PIN length will randomly regenerate all shared access codes and emergency codes, and will clear all User PIN codes.

This length must be between 4 and 8 characters. The default length is 4.

Related Topics

- [Users](#)

- [Notifications](#)
- [Events](#)
- [Audits](#)
- [Alarms](#)
- [Shared Access Codes](#)
- [Emergency Codes](#)

6. FEATURES AND TASKS

This section provides information on features which span multiple screens, and information on common tasks.

[Lockdown](#), Emergency Unlock, and [Duress](#) are used to handle [emergency situations](#).

[Reports and Printing](#) explains how to print from Sentinel Series

Use [Manual Commands](#) to directly unlock Doors or momentarily change their Door Mode.

[First Credential Unlock](#) allows the first arriving individual to completely unlock a Door.

Manage the addresses and encryption keys of [OSDP Devices](#).

Use [Card Enrollment Points](#) to enroll a User's cards by swiping the card.

[Anti-passback](#) discourages Users from loaning or sharing their access card.

[Elevators](#) can be configured to use access control to only allow access to authorized floors.

6.1. LOCKDOWN

Global lockdown is a feature to be used in emergency situations to lockdown all Doors in Sentinel Series, such that no access is allowed. [Scheduled](#) and [manually commanded](#) Door Mode changes have no effect during lockdown.

There are exceptions:

- [Doors](#) with **Exempt From Global Lockdown** checked are not affected.
- [Emergency Codes](#), and [Users](#) with **Access Doors in Lockdown Mode** checked are able to access Doors in the lockdown state.
- Exit Buttons continue to work during lockdown.
- Lockdown versus Emergency Unlock:
 - An emergency unlock will override a lockdown if the emergency unlock occurs after the lockdown.
 - A lockdown will override an emergency unlock if the lockdown occurs after the emergency unlock.
 - An emergency unlock condition will return when a lockdown is cleared, if its triggering condition is still active.

Global lockdown can be initiated through the web application, with the button on the top toolbar. There is also a button to clear the lockdown, next to it.

In [Sub-controller \(I/O\) properties](#) an auxiliary input can be configured with a Linkage to initiate a lockdown if the input becomes active. This can be used to create a physical lockdown button. Note that if a lockdown is initiated by an input, it can only be cleared using the web app.

When lockdown is initiated, an [Event](#) is generated. There is a default [Alarm Trigger](#) which generates an [Alarm](#) based on this Event.

If active, the lockdown status of Sentinel Series is clearly shown at the [top of the screen](#) (regardless of what is being viewed) - **SYSTEM UNDER LOCKDOWN!**, in red. Also, counts of locked down Controllers and Doors are shown in the dashboard statistics on the [home screen](#). Note that when a Controller is in a lockdown state, that really just means all of the Doors on the Controller are in a lockdown state (apart from the exceptions above). Any screens which show Door or Controller status will show this state ([Door Status](#), [Maps](#), etc).

In a system with a Primary and Secondary Controllers, when the Primary Controller initiates lockdown, it also initiates lockdown for all Secondary Controllers, allowing for a total system lockdown.

Individual Doors may be manually put into lockdown mode using [Manual Commands](#). Note that a Door cannot have a default or [scheduled mode](#) of lockdown.

Important: As with all emergency functions, lockdown should be tested ahead of time, to ensure that everything is configured and working correctly.

Important: Emergency exit functions are regulated by country- and region-specific fire codes. Please refer to these when designing and configuring Sentinel Series to ensure compliance.

▣ Related Topics

- [Emergency Features](#)
- Emergency Unlock

6.2. DURESS

A Duress PIN is an alternate PIN that a User can enter in place of their normal PIN to discreetly indicate duress during Door access (for example, being threatened by an intruder). Access works as normal from the User's point of view, without any indication that anything is different at the Door. The User is granted or denied access according to the same rules as usual. In the system, however, an additional Event, **Duress**, is recorded under these conditions.

The Duress [Event](#) is configured as an [Alarm Trigger](#) by default, generating an [Alarm](#).

Furthermore, the duress [Event](#) is one of the options that can be used as a Linkage to trigger the activation of an auxiliary output in the [Hardware](#) screen.

A **Duress PIN** is configured in the [Users](#) screen on a per-user basis.

The **Duress PIN** can be derived from the normal PIN automatically using the **Add 1 to Last Digit** method: For example, a normal PIN of 1111 would then correspond to a duress PIN of 1112, and a normal PIN of 9999 would then correspond to a duress PIN of 9990.

Alternatively, the **Duress PIN** can be explicitly specified.

Note that the **Duress PIN** value must be unique, also with respect to all normal PIN codes, [Shared Access Codes](#), and [Emergency Access Codes](#).

▣ Related Topics

- [Emergency Features](#)

6.3. REPORTS AND PRINTING

Printing in Sentinel Series is available as follows:

- **Export PDF** menu buttons: Some list views include this button on the menu. Wherever this option appears, you can generate a PDF of everything in the currently displayed list.

All browsers and operating systems have the ability to download, view, and print PDFs. The exact details depend on your browser and operating system.

6.4. MANUAL COMMANDS

Manual Commands is a menu button that directly commands Doors to unlock or change [Door Mode](#). The button appears on any screen where Doors are listed. The command options are:

Momentary Access Unlocks the Door momentarily for a single access

Set Door Mode Changes the [Door Mode](#).

- If **Until canceled or next scheduled change** is checked, the mode will be applied until canceled or until the next scheduled change.
- Otherwise, enter a **Duration**, specifying how long the mode change will last.

Cancel Cancels a previous manual Door Mode change that was made on this screen

☰ Related Topics

- [Door Status](#)
- [Maps \(Monitoring\)](#)
- [Doors](#)

- [Door Modes](#)

6.5. FIRST CREDENTIAL UNLOCK

[Door Modes](#) with **First Unlocks** stay locked only until the next valid access by a User with the **Allow First Credential Unlock** option checked. The Door will then unlock and stay unlocked until the next scheduled mode change (or a mode change from a Manual Command).

First credential unlock is available anywhere where Door Modes are selected.

Once a valid Card and PIN is presented, the Door will change to **Unlocked** mode. This will be visible anywhere the Door status is shown. The mode can be changed later using [Manual Commands](#).

Related Topics

- [Doors](#)
- [Door Mode Schedules](#)
- [Manual Commands](#)
- [Door Status](#)

6.6. OSDP DEVICES

OSDP devices (Readers, Sub-Controllers) have 2 important features which require special attention when configuring a system:

- an address ("polling address") which must match between the device and the controller it is connected to.
- encryption, with a configurable encryption key - which must also match between the device and the controller it is connected to.

For this configuration, the OSDP Configuration Wizard is available from the [Hardware Properties](#), [Reader Status](#), and [Sub-Controller Status](#) screens.

Address

Each OSDP device on a given serial port must have a unique address. When setting up multiple OSDP devices, which generally default to address 0, the most straightforward process is to get the first device online at address 0, then change the address to a unique nonzero address. Then repeat with the next device.

+ Encryption

By default, the Controller will use the default encryption key to communicate with OSDP devices (the only exception is OSDP devices which do not support encryption at all). Because this key is the same for all OSDP devices manufactured, a unique encryption key should be generated and used for each OSDP device.

For OSDP device in the factory default state, this default encryption key will be used on the device side as well, and the device will come online. Once online, the OSDP Configuration Wizard can be used to upload and switch to a new, unique encryption key for the device.

Before reconfiguring encryption, it is worth reviewing the OSDP device manufacturer's instructions on how to perform a factory reset on the device, in case there are any issues and the device becomes unreachable due to an encryption key mismatch, etc.

Once an encryption key is transferred to a device, the default encryption key can no longer be used with that device, unless the device is reset to the factory defaults.

+ OSDP Configuration Wizard

With either of these features (address or encryption), there may be an OSDP device which is already itself configured to use a given address or encryption key, and offline, and the Controller simply needs to know the correct value in order to bring it online and communicate with it.

Or, the OSDP device is online with a given address or encryption key, and the goal is to switch to a new address or encryption key, updating both the device and Controller to use the new value.

To assist with this process, the OSDP Configuration Wizard, shows the current status of the device throughout the process. This includes:

- whether the device is online or offline
- whether encryption is in use, and if so, whether the default encryption key is in use.

+ Set Polling Address

Note: some OSDP devices might not support this operation.

Use this option to change the OSDP address that the device itself is configured to use. This is *not* the **OSDP/RS-485 Address** the Sub-controller is set to use, though they must ultimately have the same value - see below.

The device must be online for this operation, because the new address must be communicated to the device over the existing address.

After this operation has been performed, the actual OSDP/RS-485 Address in the [Hardware Properties](#) must be set to the same new value, and the hardware configuration saved.

After this final change, the OSDP device should come back online at the new address.

▣ Upload and Switch to Encryption Key

Use this option to transfer a (new) encryption key to the OSDP device, and have the Controller start using it for communications with the device.

The device must be online for this operation, because the new key must be communicated to the device.

▣ Upload and Use Encryption Key

Use this option if the OSDP device already has an encryption key set up, but is offline because the controller does not have the matching key.

▣ Revert to Default Encryption Key

Use this option if the OSDP device has no encryption key loaded in it, but is offline because the controller is attempting to use an encryption key. This may occur when a replacement OSDP device is connected in place of a previously connected OSDP device, or when the existing OSDP device has had a factory reset.

▣ Related Topics

[Hardware Properties](#)

[Reader Status](#)

[Sub-Controller Status](#)

6.7. CARD ENROLLMENT POINTS

You can designate readers to use for adding cards to a User without typing in a card number. You might not even know the card number. These are called Card Enrollment Points and are a type of Door. You can also use any card reader at all to create cards for new Users.

Set Up a Card Enrollment Point

You need a Controller with a Configuration that includes "+ Card Enrollment Point". You can do this when you [add a Controller](#), or you can [modify](#) an existing Controller. When this is done, one of the Controller's Doors will be an Card Enrollment Point.

Each User may select one Card Enrollment Point to use. Select your choice under [Menu: Preferences](#).

Using a Card Enrollment Point

While on the [Users](#) screen,

1. Click **Add** next to the **Cards** box.
2. Click in the **Card Number** field.
3. Swipe the card at the Card Enrollment Point.

▣ Using Any Reader to Enroll

Any card reader in the system can be used to enroll a completely new User, or to find out the number of a card.

1. Swipe the card at any reader.
2. Go to the [Events](#) screen.
3. Find the corresponding **Access Denied (Unknown Card Number)** Event. The card number is shown in the User column.
4. Click the card number to create a new User having this card.

If the card is currently assigned to another User, you will get some different Event.

▣ Related Topics

[Hardware](#)

[Users](#)

6.8. ANTI-PASSBACK

Use anti-passback to prevent or detect Users going through the same Door twice in a row, without either exiting from the Area or waiting for the specified time period. For example, Users can enter through an Area with security screening, but must exit through a different Area.

Anti-passback is intended to prevent someone from "passing back" a credential for another person to use it at the same Door, or to another Door entering the same Area. This is commonly used with turnstiles and other special entry devices. Area-based anti-passback can also help prevent sharing of PINs. However, with a normal Door there is no way to prevent one User from simply holding it open for another.

If an access attempt is made which violates anti-passback rules, this will always create an [Event](#). The User may or may not be denied access depending on the configuration.

There are two methods of anti-passback enforcement.

- Door-based — A Door can be opened by the same credential only once during a set time period.
- Area-based — Area-based anti-passback tracks the location of a User and generates a violation if their credential is used somewhere else. For example, if Door 1 exits Area A and enters Area B, and Door 2 exits Area B and enters Area C, then presenting the same credential at Door 1, then Door 2, then Door 1 again is an anti-passback violation, because the User is known to be in Area C when attempting to use a Door which exits Area A.

Note: Anti-passback does not apply to [Shared Access Codes](#), [Emergency Codes](#) or anti-passback exempt Users (see below).

▣ Defining Anti-passback Areas

In the [Areas](#) screen, you can define the Areas to use for anti-passback. You can also use the pre-defined Areas, such as Global Out.

▣ Configuring Anti-passback Doors

In the [Doors](#) screen, you can define the entering and exiting Areas and the anti-passback settings.

1. Go to [Doors](#).
2. Under Areas and Anti-passback:
 - a. Select the **Entering Area**. This is the [Area](#) that the Door enters into
 - b. Select the **Existing Area**. This is the [Area](#) that the Door exits from.
3. Select the Anti-passback Method:
 - a. **Area-Based** — Anti-passback is enforced at this Door using any entry to or exit from the Area. Select an anti-passback mode to grant or deny access.
 - b. **Door-Based** — Anti-passback is enforced solely based on access to this Door. Enter the number of minutes the anti-passback status is reset after the User enters the Door.
4. Click **Save**.

▣ Anti-passback Exempt Users

To exclude Users from anti-passback rules, check the **Anti-passback Exempt** box on the [Users](#) screen.

▣ Forgiving Anti-passback Violations

The **Forgive** button on the [Users](#) screen resets the selected User's anti-passback status. Use this when anti-passback rules are preventing a User's access, and you determine to forgive the violation.

▣ Related Topics

- [Users](#)
- [Areas](#)
- [Doors](#)

6.9. ELEVATOR CONTROL

Elevators are integrated using [I/O Expansion Sub-Controllers](#) which provide additional Outputs.

Each Output is wired to the elevator control module, with each Output connected to a corresponding floor button.

An Door is also associated with the Elevator. The physical reader associated with the Door is generally inside the elevator cab.

Within an [Access Level](#), when an Elevator Door is selected, an Elevator Floor is selected in addition to a Schedule.

When an authorized User presents a Card at an Elevator Door, the Elevator Floors which they have access to according to the [Access Level](#) are activated, which causes them to light up and be selectable by that User to go to the desired, authorized floor.

An Elevator is created by using the [Modify operation on a Controller](#) in [Hardware](#). The [I/O Expansion Sub-Controller](#) must already have been created (similarly, using **Modify**).

Once created the Elevator appears in the Elevators screen.

The Elevator Floors appear in the Elevator Floors screen.

▣ Related Topics

- Elevators
- Elevator Floors
- [Access Levels](#)
- [Hardware](#)

7. REFERENCE

Reference material:

- [Glossary](#)
- [Event Categories and Types](#)

- [Door Modes](#)

7.1. GLOSSARY

Access Level	A set of Door/Schedule pairings defining access to those Doors during the associated Schedules.
Acknowledged	When a User is aware of an Alarm, but nothing has necessarily been done about it
Airlock	A rule applying to multiple Doors in an Area restricting which Doors can be opened at the same time
Alarm	Triggered by an Event, an Alarm is like a copy of the Event which can change state from New to Acknowledged to Resolved, for the purposes of Users being made aware of the issue and keeping track of whether and which ones have been Resolved
Alarm Trigger	Triggers an Alarm from an Event
Anti-passback	A rule preventing or detecting the "passing-back" of a credential from one person to another, using the same credential twice in a row at the same Door or entering into the same Area
Audit	A record of a change made in the system by a User, or of a manual command executed by a User
Battery Monitor	An Input on a Controller configured to detect whether a battery is connected
Card	A Card is a credential encoded with a number used for electronic access control. These can come in other form factors like a fob. Also known as a "Badge"
Card Design	A graphical design, including image and text elements, some of which come from a User's record, which can be used to print on the surface of a Card. Also known as a "Badge Design"
Card Enrollment Point	A Reader configured not for access control, but rather to obtain the card number for enrollment purposes

Card Format	A technical specification of the format of the data bits encoded onto a Card, including Card Number, Facility Code, Parity. Different vendors supply different Cards encoded using different Card Formats.
Card Number	The portion of the data bits encoded on a Card corresponding to a unique, identifying number.
Controller	A physical electronic device which controls input and output for access-control.
CSV	Comma Separated Values. A text file format which is able to be imported into or exported from Microsoft Excel and other office spreadsheet programs
DHCP	Dynamic Host Configuration Protocol. A network option where a device obtains its IP Address and other networking settings automatically from a router, gateway, or other network device.
DIP switch	Dual In-line Package switch. A small switch, generally in a block of small switches, used to configure hardware settings on a device such as a Controller.
Door	A combination of Reader(s), Input(s), and Output(s) which electronically controls access to a physical door, or something functionally similar to a door, like a parking gate. Also known as an "Access Point", or "Portal"
Door Mode	The mode of operation of a Door, specifying whether the Door is simply unlocked, whether it is locked and unavailable for access, or locked and requiring the presentation of credentials to unlock it. The mode also includes which types of credentials (Card, PIN) are required.
Door Mode Schedule	A schedule with a set of time intervals (including days of the week and Special Day types), where each time interval can be associated with a Door Mode. The Door Mode Schedule can be associated with a Door to change the Door Mode automatically, according to the schedule.
Door Sensor	An Input wired to detect whether a Door is opened or closed. Also known as a "Door Contact" or "Door Position Switch".
Door Template	A set of Door properties which can be associated with multiple Doors to re-use common combinations of properties without re-entering them. Also used to change the properties of multiple Doors at once, by simply changing the associated Door Template

Duress PIN	An alternate PIN code which is used to signal a duress condition. Access is granted and denied normally as if the normal PIN was used. When access is granted using a Duress PIN, an Access Granted (Duress) Event is generated, which triggers an Alarm within the software, by default.
Emergency Code	A PIN code to be used by emergency or high-security personnel in an emergency situation to gain access to a Door, regardless of Door Mode (including Lockdown)
Event	A record of an occurrence within the system. Includes hardware and access activity. Also known as a "Transaction"
Exit Button	An Input wired to detect that the Door is being opened, or needs to be unlocked, for exit purposes. Generally located on the insecure side of the Door (the side you face when exiting). May be a button, or may be another kind of device such as a motion sensor. Also known as a "Request to Exit (REX)"
Facility Code	A number encoded onto a Card in addition to Card Number, which is used to identify a facility, customer, or batch of cards. A single company will often order Cards with the same Facility Code. The exact length and location of the Facility Code within the data bits of the card can be specified in Card Formats, and the actual Facility Code value expected can be specified there as well.
Fire Code	Laws and rules in a given country or region which specify how buildings, fire alarm systems, and other electronic systems must be designed, built, configured, and operated for life-safety purposes.
Firmware	Software which runs on an embedded device such as a Controller
Forced Open	A condition where a Door has been physically opened (according to the Door Sensor), but is also still locked. That is, it has been opened without any valid access, exit request, manual command, or Door Mode allowing it to be opened.
Hardware Template	A set of Controller properties which can be associated with multiple Controllers to re-use common combinations of properties without re-entering them. Also used to change the properties of multiple Controllers at once, by simply changing the associated Controller Template

Held Open	A condition where a Door was opened, but not closed within a set amount of time
HTTPS	A protocol for communicating between a web browser and a web server which is secured through encryption
In (Door)	A Door configured to enter (In). May be paired with an Out Door, in which case the In Door controls the shared Inputs and Outputs
In/Out	A configuration on a Controller with 2 Doors, one for entry (In), and one for exit (Out). These 2 Doors represent 2 sides of the physical door.
Input	An electronic input on a Controller which can detect a circuit being active or inactive.
IP Address	A numeric address for devices and computers on a network
Linkage	A rule linking Events and conditions to actions or outputs. Also known as a "Policy"
Location	A label indicating a Location name, which can be arranged in a hierarchy, to organize Hardware, Doors, Areas, and Maps.
Lock	An Output on a Controller configured to connect to a physical electronic door lock. Also known as a "Door Strike"
Lockdown	An emergency state for a Door or Controller where the Door (or all Doors associated with the Controller) are locked and deny access to all credentials (with some exceptions). Lockdown is unaffected by scheduled Door Mode changes as well as normal Manual Commands.
Manual Command	A command executed by a User in the web application which affects a Door or Controller. Examples include momentarily allowing access to a Door, changing the Door Mode of a Door.
Map	A graphical layout of a facility, often with a floor plan, showing the location of Doors and Controllers, with their status.
Multi-User Access	Rules that require multiple Users from multiple User Groups to access a Door.
Muster	A report showing the last-known access of each User, if that access is not to the Global Out or Muster Areas.

Muster Point	A Door which is used simply to record that a User has reached the Muster Area, for Muster report purposes
Normally Closed (NC)	A type of Input configuration where the normal, "Inactive" condition of the input is where the circuit is closed. Inputs which are typically Normally Closed are Door Sensor, Tamper, Power Monitor, Battery Monitor
Normally Open (NO)	A type of Input configuration where the normal, "Inactive" condition of the input is where the circuit is closed. Inputs which are typically Normally Closed are Door Sensor, Tamper, Power Monitor, Battery Monitor
Notification	An in-application copy of certain Events subscribed to by each User. A copy of Notifications can also be configured to be sent via email.
NTP	Network Time Protocol. A protocol for synchronizing time to computers and devices on a network or the Internet. NTP Servers provide reliable, accurate time to devices and computers which subscribe to their services.
OSDP	Open Supervised Device Protocol. A standard protocol for connecting Readers to Controllers using RS-485.
Out (Door)	A Door configured to exit (Out), which is always paired with a Door for entry (In). The In Door is the one controlling the shared Inputs and Outputs.
Output	An electronic output on a Controller which functions as a electronic switch, and can control other devices, like a Lock
Parity	A type of data bit within a Card Format which is used to ensure the integrity of the data read. A parity bit acts as a check on a set of binary values, calculated in such a way that the number of 1s in the set plus the parity bit should always be even (or occasionally, should always be odd).
PDF	Portable Document Format. A format used for documents or reports which can be easily viewed or printed on a PC.
PIN	Personal Identification Number. A credential consisting of a numeric code to be entered on a reader's keypad for identification or verification purposes.

Policy	A rule linking Events and conditions to actions or outputs. Also known as a "Linkage"
Power Monitor	An Input on a Controller configured to detect whether the main power is connected
Primary Controller	The Controller in the system which maintains the entire system configuration, and hosts the web application used to access, configure, and monitor it. A Primary Controller can manage multiple Secondary Controllers.
Reader	Reads cards or credentials, including possibly Card, or PIN.
Resolved	The state of an Alarm which means that it has been fully resolved, that is, it is no longer an issue that needs attention or needs to be visible.
REX	Request to Exit. Another term for Exit Button.
RS-485	A serial communications protocol used for communications between devices, including between Controllers and Readers. OSDP uses the RS-485 protocol, for example.
Schedule	A set of time intervals (including days of the week and Special Day types), used to regulate Door access by time
Secondary Controller	A Controller which obtains its configuration from a Primary Controller
Shared Access Code	A PIN code shared by a group of people, used gain access to a Door.
SMTP Server	An email server for sending email
Special Day	A day on the calendar (for example a holiday) where normal Door access is to be disallowed by default, unless the Schedule explicitly indicates that Special Days are allowed
Special Day Type	A category or grouping of Special Days.
SSL	Another term for TLS, a networking encryption protocol
Sub-controller	A type of Controller which manages inputs and outputs (I/O) but does not make access or other decisions by itself. Sub-controllers can be built-into the controllers, or separate physical devices.

Tamper	An Input on a Controller configured to detect physical tampering with a case, enclosure, etc.
TLS	A networking encryption protocol
User Role	A set of permissions for what a User can and cannot do when logged into the web application.
User Group	A classification or grouping of Users used for Multi-User Access.
Wiegand	A standard protocol for connecting Readers to Controllers

7.2. EVENT CATEGORIES AND TYPES

Event Colors:

- **Red**: Event is also an [Alarm Trigger](#) by default. If you create additional alarm triggers, those events will appear red in Sentinel Series. If you remove built-in triggers, those events will appear yellow.
- **Yellow**: Warnings
- **Green**: Normal access granted
- White: Informational

System

Card Read (Enrollment)	A Card has been read on an Enrollment Point
Controller Resync	Data resynchronized to a Controller
Controller Startup	Controller started up
Database Backup Copied to USB Drive	Database backup copied to USB drive
Database Backup Copy to USB Drive Failed	Database backup copy to USB drive failed
Software Update Failed	Software update failed
Software Updated	Software updated
Schedule Active	Schedule became active
Schedule Inactive	Schedule became inactive

Signed Out	A User signed out of the application
Successful Sign In	A User signed in successfully to the application
Unsuccessful Sign In	A User unsuccessfully attempted to sign in to the application - generic
Unsuccessful Sign In (Expired)	A User unsuccessfully attempted to sign in to the application - expired
Unsuccessful Sign In (Inactive)	A User unsuccessfully attempted to sign in to the application - inactive login
Unsuccessful Sign In (Inactive User)	A User unsuccessfully attempted to sign in to the application - inactive User
Unsuccessful Sign In (Incorrect Password)	A User unsuccessfully attempted to sign in to the application - incorrect password
Unsuccessful Sign In (No Privileges)	A User unsuccessfully attempted to sign in to the application - no User Roles
Unsuccessful Sign In (Not Yet Effective)	A User unsuccessfully attempted to sign in to the application - not yet effective
Unsuccessful Sign In (Outside Schedule)	A User unsuccessfully attempted to sign in to the application - outside schedule
Unsuccessful Sign In (Too Many Denied Attempts)	A User unsuccessfully attempted to sign in to the application - too many denied attempts
Unsuccessful Sign In (Too Many Incorrect Password Attempts)	A User unsuccessfully attempted to sign in to the application - too many incorrect password attempts
Unsuccessful Sign In (User Expired)	A User unsuccessfully attempted to sign in to the application - After Valid To of User
Unsuccessful Sign In (User Not Yet Effective)	A User unsuccessfully attempted to sign in to the application - Before Valid From of User

Access Granted	Generic
Access Granted (Door Already Open)	Door already open

Access Denied

Access Denied	Generic
Access Denied (Airlock Busy)	Airlock rules would be violated by the access (another Door in the Airlock-configured Area is unlocked/open)
Access Denied (Anti-passback)	Anti-passback violation
Access Denied (Expired)	After Valid To of Card or other credential
Access Denied (Inactive)	Card Inactive
Access Denied (Inactive User)	User is inactive
Access Denied (Incomplete)	Credentials incompletely presented (for example partial PIN digits)
Access Denied (Incorrect Card)	Door Mode requires/allows Card to be presented after PIN, but the Card does not match that PIN
Access Denied (Incorrect Confirming PIN)	Door Mode requires confirming PIN, but confirming PIN entered does not match
Access Denied (Incorrect Facility Code)	Card Format recognized, but Facility Code does not match
Access Denied (Lockdown)	Door Mode is Lockdown
Access Denied (No Access)	Door Mode is No Access
Access Denied (No Card Access)	Door Mode does not allow Card, but Card presented
Access Denied (No Card Presented)	Door Mode requires Card, but no Card presented.
Access Denied (No Confirming PIN Defined)	Door Mode requires PIN, but User has no PIN defined

Access Denied (No PIN Access)	Door Mode does not allow PIN, but PIN presented
Access Denied (No PIN Presented)	Door Mode requires PIN, but no PIN presented
Access Denied (No Privileges)	No matching Access Level or Door/Schedule assignment
Access Denied (Not Yet Effective)	Before Valid From of Card or other credential
Access Denied (Outside Schedule)	Matching Access Level or Door assignment, but Schedule is inactive
Access Denied (Unknown Card Number)	Unknown card number
Access Denied (Unknown Format)	Bit pattern of data bits on card does not match any defined, enabled Card Format
Access Denied (Unknown Unique PIN)	Unknown PIN used for PIN-only or PIN-first access
Access Denied (User Expired)	After Valid To of User
Access Denied (User Not Yet Effective)	Before Valid From of User

☰ Communications

Controller Offline	Controller offline (Secondary Controller, Sub-controller (I/O)
Controller Online	Controller online (Secondary Controller, Sub-controller (I/O)
Reader Offline	Reader offline (OSDP, RS-485)
Reader Online	Reader online (OSDP, RS-485)

☰ Door

Controller Access Mode: Lockdown	Lockdown at the Controller level
Controller Access Mode: None	Emergency Unlock or Lockdown at the Controller level cleared

Controller Access Mode: Unlocked (Emergency)	Emergency Unlock at the Controller level
Door Closed	Door closed (according to Door Sensor)
Door Forced Masked	Door Forced Open condition being masked (no indication as to whether the underlying condition is present or not)
Door Forced Open	Door opened while not unlocked
Door Forced Open Restored	Door Forced Open condition not present or no longer present
Door Forced Unmasked	Door Forced Open condition not being masked (condition will be reported if present)
Door Held Masked	Door Held Open condition being masked (no indication as to whether the underlying condition is present or not)
Door Held Open	Door held open too long after being opened
Door Held Open Restored	Door Held Open condition not present or no longer present
Door Held Open Warning	Warning prior to Door held open too long after being opened
Door Held Unmasked	Door Held Open condition not being masked (condition will be reported if present)
Door Mode: Card and PIN	Door Mode indication
Door Mode: Card and PIN (First Unlocks)	Door Mode indication
Door Mode: Card Only	Door Mode indication
Door Mode: Card Only (First Unlocks)	Door Mode indication
Door Mode: Card or PIN	Door Mode indication
Door Mode: Card or PIN (First Unlocks)	Door Mode indication
Door Mode: Lockdown	Door Mode indication

Door Mode: No Access	Door Mode indication
Door Mode: No Access, No Exit Button	Door Mode indication
Door Mode: PIN Only	Door Mode indication
Door Mode: PIN Only (First Unlocks)	Door Mode indication
Door Mode: Unlocked	Door Mode indication
Door Mode: Unlocked (Emergency)	Door Mode indication
Door Momentarily Unlocked	Momentary Access Manual Command sent from application
Door Momentary Access Denied	Momentary Access Manual Command sent from application - not executed (denied) - generic
Door Momentary Access Denied (Airlock Busy)	Momentary Access Manual Command sent from application - not executed (denied), because it would violate Airlock rules (another Door in the Airlock-configured Area is unlocked/open)
Door Monitored Open	Monitor Open Only Door: open while monitored
Door Monitored Open Masked	Monitor Open Only Door: Door Monitored Open condition being masked (no indication as to whether the underlying condition is present or not)
Door Monitored Open Unmasked	Monitor Open Only Door: Door Monitored Open condition not being masked (condition will be reported if present)
Door Not Monitored Open	Monitor Open Only Door: closed while monitored (or no longer being monitored)
Door Opened	Door opened (according to Door Sensor)
Duress	Duress (Duress PIN was entered)
Emergency Code Presented	Emergency Code Presented

Exit Request Denied	Exit Button active, but exit access not triggered - generic
Exit Request Denied (Airlock Busy)	Exit Button active, but exit access not triggered, because it would violate Airlock rules (another Door in the Airlock-configured Area is unlocked/open)
Exit Requested	Exit Button active, triggering exit access
Exit Requested (Door Already Open)	Exit Button active, triggering exit access - Door is already open
Door Momentarily Unlocked (Door Already Open)	Momentary Access Manual Command sent from application - Door is already open
Global Access Mode: Lockdown	Lockdown at the Global level
Global Access Mode: None	Emergency Unlock or Lockdown at the Global level cleared
Global Access Mode: Unlocked (Emergency)	Emergency Unlock at the Global level

Input/Output

Input Active	Input inactive
Input Inactive	Output inactive
Output Active	Output active
Output Inactive	Output inactive

Tamper/Power

Battery Failure	Battery Monitor Input is active
Battery Restored	Battery Monitor Input is inactive
Off Main Power	Power Monitor Input is active
On Main Power	Power Monitor Input is inactive
Tamper	Tamper Input is active

Tamper Restored

Tamper Input is inactive

7.3. DOOR MODES

The Door Mode determines whether or not the Door is in an unchanging state (**Unlocked, Unlocked (Emergency), No Access, Lockdown**), or in an access-controlled state, requiring credential presentation for access. When credentials are required, the Door Mode also determines which types of credentials are required.

When the Door Mode is initially set for a Door, or it changes, a corresponding [Event](#) is generated (See: [Event Categories and Types](#)). For example, if the Door Mode becomes **Card Only**, an Event will be generated: **Door Mode: Card Only**.

The default Door Mode for a Door is set in the [Doors](#) screen.

[Door Mode Schedules](#) can be used to automatically change Door Modes according to a schedule.

[Manual Commands](#) can be used to set the Door Mode.

The Door Mode is also shown in [Door Status](#) and anywhere the status of a Door is shown ([Doors](#), [Maps](#)).

Most access-controlled Door Modes have a (**First Unlocks**) variant. See [First Credential Unlock](#) for details.

The following is a list of all Door Modes for a Door:

- **Unlocked**
- **Unlocked (Emergency)**
- **No Access**
- **Lockdown**
- **No Access, No Exit Button**
- **Card Only**
- **Card Only (First Unlocks)**
- **Card and PIN**

- **Card and PIN (First Unlocks)**
- **PIN Only**
- **Pin Only (First Unlocks)**
- **Card or PIN**
- **Card or PIN (First Unlocks)**

Note that a Controller can be placed in a special Door Mode during global [Lockdown](#) and Emergency Unlock. The Events generated for this at the global level are:

- **Global Access Mode: Unlocked (Emergency)**
- **Global Access Mode: Lockdown**
- **Global Access Mode: None**

The Events generated for this at the Controller level are:

- **Controller Access Mode: Unlocked (Emergency)**
- **Controller Access Mode: Lockdown**
- **Controller Access Mode: None**

☰ Related Topics

- [Doors](#)
- [Door Mode Schedules](#)
- [Manual Commands](#)
- [First Credential Unlock](#)
- [Lockdown](#)
- Emergency Unlock
- [Events](#)
- [Event Categories and Types](#)